

February 2011 Ice Storm Damages

DHS – Broken fire sprinkler lines in the greenhouse with minimal water damage.

DHS Press Box – Broken fire sprinkler lines and multiple domestic water lines, no water damage. The water was turned off before it thawed to save a flood.

DHS – Broken water lines in SW concession stand at Bronco Field. This is inside a block wall and may take major work to make repairs.

Calhoun Cafeteria – Broken water line on loading dock with no water damage. Repairs have been completed.

Rivera – Broken chill water line outside in the equipment yard with no water damage.

Transportation – Broken water line to portable, not water damage. The repairs have been completed.

Borman – Broken water line to sink on exterior wall, with water damage to 9 classrooms. The clean-up is in progress. The water line has been repaired.

Wilson – Roof leak in the music room with water damage confined to that area only. The clean-up is in progress. The roof leak was a roof drain and the repair has been completed.

Ginnings – Broken water line under the building. No water damage to the inside of the building. The repair has been completed.

CH Collins – Major water damage due to multiple broken fire sprinkler lines in the main building. The entire building flooded. All flooring will need to be replaced, sheetrock ceiling and drop ceiling needs replacing, and A/C duct insulation needs replacing. All work is in progress at this time. There were also broken fire sprinkler lines in a couple of the concession stands with minor water damage in one of the concession stands.

Paul Andress met with TASB on February 8, 2011 and documented the damages. They are working on the claim at this time.