
maintenance and ground report

Striker Hasson <shasson@badger.k12.mn.us>

Mon, Dec 11, 2023 at 9:51 AM

To: Kevin Ricke <kricke@badger.k12.mn.us>

fixes in november and december

- 1) OHU in shoproom, welding area sprung a leak in the heating coil, patched and leak tested on 12-6
- 2) walk in freezer- was losing freon- started in november, found a leak on the solenoid. replaced solenoid and added freon to get up working
- 3) bad low water cutoff on old boiler, ordered and replaced the old low water cutoff. will be switching over boilers at the end of the week

Striker Hasson

Head of Maintenance and Grounds

Head Football Coach

shasson@badger.k12.mn.us

218-528-3201 ext. 208