

New Berlin CUSD #16 Facilities Work Progress Report for **New Berlin Elementary** Board Report for March 2022

Work to Begin or in Progress	Description	Update
had boiler inspections completed		
kitchen cooler cooling problems	topped off freon	
Repaired Geo Leak in 309 Ceiling	actuator valve seal leaking, replaced control valve	
repaired floor scrubber	bearing out of main castor, replaced	
set up for numerous metings in MP room		
repaired fogger backpack	electrical short in switch	replaced switch
removed all 4 Admin office doors, take to shed	had Glass company install glass panel kits	complete
set up gym for four different concerts	KG, 4th, band, choir	
recieved book fair materials		
summerize all snow removal equipment		
remove snow plows		
cleaned out and organize outside storage shed		
fogged kitchen during Easter break	natural odor/ mold treatment	
searched, ordered lockers for teacher lounge	to be assigned to paraprofessional,s	

