

MAINTENANCE REPORT OCTOBER 2023

Submitted by: Reid Reagan

Maintenance staff has been installing the new AED (Automated External Defibrillator) throughout the facilities. Responded to 87 work orders, all service or repair calls.

BHS:

Remove faulty hot water heater, install new heater. Clean softball field at sportsplex by removing the packed dirt and rubber beads by pressure washing, spread new rubber beads and comb beads into turf.

BMS:

Cleanout the clogged strainers in several classrooms of 7th grade pod.

NAPI:

Caulk windows to aluminum clad frames to reseal.

KWB:

Patch roof leak with asphalt patch, tighten loose clamp on rubber boot on the roof drain.

BABB:

Patch roof leaks with asphalt patch, repair metal roofing with metal panels. Dig up shrubs/brush in the right-of-way of new fence. Install new dishwasher rinse hose.