

Topic: Replacement of Fire Alarm Panels at Arnold MS, Daniels ES , and Jackson MS

Submitted by: Joel Falcon, Chief of Operations

Approved for Transmittal:

Board Meeting Date: 3/13/2025

Recommendation:

It is recommended that the Board of Trustees approve the replacement of fire panels at Arnold Middle School, Daniels Elementary, and Jackson Middle School through quotes with vendor Firetrol in the amount of \$146,036.00.

Rationale:

Fire alarm panels now in use are obsolete, and parts are no longer available.

Budget Information:

General Fund

Board Policy Reference and Compliance:

CH(LOCAL) CH(LOCAL)