

No. \_\_\_\_\_



## UNITED INDEPENDENT SCHOOL DISTRICT AGENDA ACTION ITEM

**TOPIC:** Consideration for Approval of Request from the City of Laredo Utilities Department for Upsizing the Waterline at United Avenue

**SUBMITTED BY:** Enrique Rangel **OE:** Facilities Dept

**APPROVED FOR TRANSMITTAL TO SCHOOL BOARD:** \_\_\_\_\_

**DATE ASSIGNED FOR BOARD CONSIDERATION:** \_\_\_\_\_

**RECOMMENDATION:**

Administration recommends approval of request from the City of Laredo Utilities Department for increasing the size of the water line proposed for the United Avenue project from a 12" line to a 16" line.

**RATIONALE:**

See attached request letter from Mr. Tomas Rodriguez, City of Laredo Utilities Director

**BUDGETARY INFORMATION:**

No Cost Incurred

**BOARD POLICY REFERENCE AND COMPLIANCE: CV**

# CITY OF LAREDO

Water Utilities Department

5816 Daugherty  
Laredo, Texas 78041  
Ph. (956) 721-2000



P.O. Box 2950  
Laredo, Texas 78044  
Fax: (956) 721-2001

**February 4, 2009**

**United Independent School District  
ATTN: Enrique Rangel, P.E.  
3501 E. Saunders St.  
Laredo, Texas 78041**

**RE: UISD High School**

**Dear Mr. Rangel:**

**This is to inform you that we approve your request to install a 12" water line to provide water to the school.**

**Based on our future plans, we would like to ask you to install a 16" water transmission main with valves instead of a 12" line. This letter will serve as our formal offer to provide the 16" PVC pipe, valves and fittings to your contractor provided you deliver the 12" pipe, valves and fittings to our yard at 5816 Daugherty.**

**Basically, the City will provide the matereial needed in order to upgrade the Water Distribution system in North Laredo.**

**Expecting this meets with your approval, I remain**

**Yours truly,**

**Tomas M. Rodriguez, Jr P.E.  
Water Utilities Director**