

# CERTIFICATE OF APPROVAL FOR A TEN YEAR SURVEY REPORT

(Section 2-3.12 of the School Code)

DISTRICT OFFICE	McLean
School Building	County
McLean County USD 5, 0050	
District Name and Number	

I, , State Superintendent of Education, acknowledge receipt of this ten-year safety survey report, approved for the year 0. Hence, the next safety survey report will be due in the year 0. The District architect has provided assurances that the building named above has been surveyed in accordance with 105 ILCS 5/2-3.12. This Certificate of Approval for a Ten Year survey Report does not necessarily imply that Fire Prevention and Safety Funds can be used for the work items listed in this survey report.

Date	Signature of State Superintendent of Education

COMMENTS:

ITEM ID	DESCRIPTION	ESTIMATED AMOUNT	ADJUSTED AMOUNT	DIFFERENCE	REASON
---------	-------------	------------------	-----------------	------------	--------

OTHER COMMENTS:

ITEM ID	DESCRIPTION	REASON
---------	-------------	--------

# CERTIFICATE OF APPROVAL FOR THE EXPENDITURE OF FIRE PREVENTION AND SAFETY FUNDS

(Section 17-2.11 of the School Code)

DISTRICT OFFICE	McLean
School Building	County
McLean County USD 5, 0050	
District Name and Number	
Amendment Number 4	

Total Previously Approved	
Approved to raise with this Amendment	\$3,000.00
Total Approved to Date	\$3,000.00
Existing District Funds Approved	\$0.00

I, , State Superintendent of Education, acknowledge receipt of the estimate of cost certified by the architect/engineer required:

1.	<input type="checkbox"/>	to bring this school building into compliance with the safety standards set forth in 23 Ill. Adm. Code Part 175, 23 Ill. Adm. Code Part 180, and or 23 Ill. Adm. Code Part 185 as promulgated by the State Board of Education.
2.	<input type="checkbox"/>	to bring the school building into compliance with the Asbestos Abatement Act 105 ILCS 105/1 et.seq, and the federal Asbestos Hazard Emergency Response Act of 1986 as amended (AHERA).
3.	<input type="checkbox"/>	to provide funds for energy conservation; disabled accessibility; school security; repair of school sidewalks, playgrounds, parking lots, or school bus turnarounds; and other repair purposes pursuant to Section 17-2.11 of the School Code with funds not necessary for the completion of items under No. 1 or No. 2 above.

I Further certify that the estimate of total approval to date, in the amount of \$3,000.00 has been examined and determined to be reasonable and is hereby approved.

Date	Signature of State Superintendent of Education

**EXPLANATORY NOTES:**

1.	<input checked="" type="checkbox"/>	No items in this amendment were disapproved nor were any of the estimated costs adjusted.
2.	<input type="checkbox"/>	One or more items in this amendment were disapproved and the estimated costs adjusted accordingly. The amount shown above as the total amount approved for this amendment reflects an aggregate cost adjustment of + / - \$0.00. Comments regarding this amendment and a list of the items disapproved and cost adjustments applied are attached to this certificate.

**COMMENTS:**

**ADJUSTED ITEMS:**

ITEM ID	DESCRIPTION	ESTIMATED AMOUNT	ADJUSTED AMOUNT	DIFFERENCE	REASON
---------	-------------	------------------	-----------------	------------	--------

**APPLICATION FOR APPROVAL OF  
TEN-YEAR SAFETY SURVEY REPORT**

(23 IL. Adm. Code Part 180, Sections. 180.310, 180.320, 180.330, 180.340)

<b>NAME OF SCHOOL BUILDING</b> DISTRICT OFFICE	<b>SURVEY YEAR</b> 2026
<b>NAME AND NUMBER OF SCHOOL DISTRICT</b> McLean County USD 5, 0050	<b>COUNTY</b> McLean
<b>ARCHITECT NAME</b> Randall Middleton	<b>FIRM</b> MIDDLETON ASSOCIATES INC.
<b>FIRM ADDRESS</b> 1702 W. COLLEGE AVE, NORMAL, IL 61761-3028	<b>TELEPHONE NUMBER</b> (309) 452-1271

I certify that the survey referred to herein was prepared by me and to the best of my knowledge is a true and accurate.

☐ Building in Full Compliance.

☒ Building Not in Compliance



9/18/2025      Randall Middleton  
Date      Printed Name Architect/Engineer

\_\_\_\_\_  
Date      President of Board of Education

\_\_\_\_\_  
Date      Secretary of Board of Education

11/30/2026      001-007938  
Expiration Date      License Number

[Seal and Signature]

Failure to submit accurate and complete safety survey reports as required shall subject a school district to the recognition provisions of 23 Illinois Administrative Code 180.



# REQUEST FOR AUTHORIZATION To use Fire Prevention and Safety Funds

Amendment Number \_\_\_\_\_

## PART I. CERTIFICATION OF ESTIMATED COSTS


This is to certify that:

The DISTRICT OFFICE school, located at 1809 W Hovey Normal, Illinois, and under the management and control of the Board of Education of School District # 0050, McLean County, was surveyed by me on 9/18/2025.

- ☐ All of the urgent or necessary work as indicated on the attached Form 35-48 is necessary to abate the violations of applicable code requirements and should result in effecting compliance with said requirements within prescribed timelines. No violations of applicable code requirements other than those cited in previously approved safety survey reports or amendments and those noted in this survey or amendment were noted.

☒ All other work recommended in the attached Form 35-48, though not required to abate violations of applicable requirements of the Health/Life Safety Code for Public Schools, is recommended for energy conservation; disabled accessibility; school security; repair of school sidewalks, playgrounds, parking lots, or school bus turnarounds; and other repair purposes provided in Section 17.2.11 of the School Code.

The certified estimated cost figures were prepared by me and to the best of my knowledge are true and accurate estimates of the costs to execute the work as specified. The total estimated costs to finance the work involved is \$ 3,000.00.

Name of Architect/Engineer Randall Middleton	Name of Firm MIDDLETON ASSOCIATES INC.
Phone Number (309) 452-1271	Fax Number (309) 454-8049.
License Number 001-007938	Expiration Date 11/30/2026
Email Address rand@miltonassociates.net	 (Seal and Signature)



## PART II. CERTIFICATION OF NEED (Provided by district through IWAS)

The local Board of Education hereby certifies and assures the State Board of Education:

- Based upon the report of the architect referred to above, the district faces total estimated costs of \$ to finance the work involved.
- The district has \$ available in its operations and maintenance fund, fire prevention and safety fund, school facility occupation tax fund and/or other fund to finance the work.
- If Fire Prevention and Safety funds are to be used, the district certifies that it has levied the maximum authorized rate for its operations and maintenance fund for the most recent year for which tax rates are available.
- The district needs to raise \$ in additional revenue through the levy of the Fire Prevention and Safety Tax or issuance of Bonds to finance the recommended work.
- Plans and specifications for the work will be submitted to the Regional Superintendent for review and approval.
- The work to be financed with Fire Prevention and Safety funds will not commence until the Certificate of Approval of the State Superintendent is received, the detailed plans and specifications have been approved by the regional superintendent and the regional superintendent (or other lawful agency) has issued an appropriate Order to Effect Compliance with the Health/Life Safety Code for public schools (or other lawful order requiring the work to be done).
- All work authorized by the District will be executed in conformity with all applicable codes.
- In the case of work recommended to repair school sidewalks, playgrounds, parking lots, or school bus turnarounds the notice and hearing requirements of Section 17-2.11 of the School Code were complied with by publishing the required notice on and holding the required public hearing on .

VIOLATION AND RECOMMENDATION SCHEDULE

(23 IL Adm. Code 180, Sections 180.320)

1. COUNTY CODE 064, McLean				2. DISTRICT CODE/NAME 0050, McLean County USD 5		3. FACILITY CODE/NAME DISTRICT OFFICE	
4. Item ID	5. Location(s) (Room No)	6. Priority Code	7. Rule Violated	8. Description of the violation			9. Recommendation to correct violation
1	Electrical Room 029	c.	175.60	There is an opening in the ceiling about 4' X 4'. A significant volume of cooled air is flowing from the opening. It is assumed that there is an opening in the duct either intended or unintended that is allowing this uncontrolled cool air into the room. It is possible that this is intended to cool the Server, but it is about 8' away from the Server racks.			Determine if the opening in the ceiling is intentional.

SCHEDULE OF RECOMMENDED WORK ITEMS AND ESTIMATED COSTS

1. COUNTY CODE			2. DISTRICT CODE/NAME				3. FACILITY CODE/NAME				
064, McLean			0050, McLean County USD 5				DISTRICT OFFICE				
4. Item I.D.	5. Action I.D.	6. Priority Code	7. Specification(s)	8. Units Of Measure	9. Quantity	10. Labor Code	11. Estimated Cost (Architect / Engineer)	12. ROE Adjustment	13. ISBE Adjustment	14. Estimated Completion Date	15. Funding Type
1	f	c.	Install a duct and difuser ro control the flow of air and reinstall ceiling grid and panels to provid smoke and flame protection in this room.	sq. ft.	16	2	\$2,500.00			1/15/2026	F

	Original Subtotal	\$2,500.00	Adjusted Subtotal	\$2,500.00	
	Original 10.00% Contingency	\$250.00	Adjusted 10.00% Contingency	\$250.00	
	Original 10.00% A/E Fees	\$250.00	Adjusted 10.00% A/E Fees	\$250.00	
	Original Grand Total	\$3,000.00	Adjusted Grand Total	\$3,000.00	

Items with a Funding Type of 'O' are not included in the cost calculation.  
35-48 (7/07) (Prescribed by ISBE for Local Board Use)