

Professional Project Management Firm

то:	Dr. Cone , Superintendent of Schools, LVISD	FROM:	Catherine BlacklerCatherine BlacklerSenior Project Manager, AGCM
cc:	Belinda Raindl, LVISD		Michael Rogers, AGCM
RE:	La Vernia ISD – Bond 2023	DATE:	June 18, 2025
SUBJECT:	PR No. 13	PR DATE:	April 21, 2025
PR COST:	<\$ 13,782.00>	CONTRACTOR:	Bartlett Cocke (RCO 12)

Dear Dr. Cone,

Bartlett Cocke (BC) submitted a proposal for the scope changes outlined in **PR No. 13**, dated **April 21, 2025**, with a total proposed is a credit for **THIRTEEN THOUSAND SEVEN HUNDRED EIGHTY-TWO DOLLARS AND 00/100** (\$ 13,782.00).

AGCM performed a comprehensive analysis that included overlaying drawings to confirm the correct scope, verifying quantities, labor hours, and allowable markup. The submitted pricing reflects updates based on feedback from both Pfluger and AGCM. Labor, materials, equipment, and allowable markup are all included. Funding for these changes will be drawn from the contingencies within the GMP and will not result in a Change Order to the contract.

1. SOURCE of SCOPE CHANGE:

The outlets at the science tables at the Junior High science room were deemed unnecessary and have been removed from the scope.

This change results in a credit to the project.

3.	TRADE PARTNERS PRICING: i. IES Commercial	Electrical	<\$13,782.00>
4.	FUNDING SOURCE: a. GMP – Owner Contingency		13,782.00
5.	PROJECTED CONTINGENCY (After PR Appro a. GMP – Owner Contingency	oval):	1,423,666.54

Based on this analysis, AGCM has no objections to the cost, or the supporting documentation as submitted. If you have any questions or require further information, please let me know.

Sincerely, AGCM, Inc.

•

Catherine Blacklen

Catherine Blackler Senior Project Manager

Attachment: PR 08 - RCO 13R1 Bartlett Cocke /cb

Request for Change Order



La Vernia ISD 2023 Bond Projects (231091) No. RCO0012 , Printed: June 18, 2025 Description PR#13 - Electrical Credit per RFI026 Date 2025-05-05 Status: Pending Review Days Impact:

Scope of Work

Provide a credit for the removal of (14)-fourteen GFI Outlets on dedicated circuits per the A/E team response to RFI026. This credit of \$13,782.00 will be taken from the electrical contractor scope and added to the owner contingency allowance.

RCO Detail

FromDescriptionAmount (\$)IES Commercial, IncElectrical and Fire Alarm-13,782.00Owner Contingency13,782.0013,782.00

Total (\$)

Submitted:

Bartlett Cocke General Contractors LLC

By:Alexander Ragland; Asst. Project Manager

Date: 6/18/2025

Approved:

Pfluger Architects, Inc

Ву: _____

\$0.00

Date:

AGCM PR REVIEW No Exceptions Taken

06/19/2025 11:07:59 AM

Catherine Blackler SNR PM

CONTRACTOR: PROJECT: DESCRIPTION:	BARTETT COCKE LA VERNIA ISD 2024					DATE.		-
	LA VERNIA ISD 2024					DATE:	5/5/202	25
DESCRIPTION:		LA VERNIA ISD 2024 JOB #: 2311240018						0018
	PR#13, DELETE 14 G INTERMEDIATE CAM	IN ROOM D116, SCIENCE LAB TABLES.						
	DESCRIPTION		QUANTITY		MAT. UNIT	MAT. EXT.	LABOR UNIT	LABOR EXT.
3/4" EMT	DESCRIPTION		-600		\$0.96	-\$576.00	0.122	-73.20
4" EMT CONN			-28		\$0.34	-\$9.52	0.122	-/3.20
/4" EMT COUP	· · ·		-28	\vdash	<u>\$0.34</u> \$0.42	-\$21.00	┨ ┿	
/4" EMT STRAP			-60	├──-}	<u>\$0.42</u> \$0.25	-\$21.00	+	
SQ BOX			-14	╞──┠	\$0.25	-\$6.44	0.340	-4.76
" SQ PLASRTER R	ING		-14	╞──┼	<u>\$0.40</u> \$0.45	-\$6.30	0.180	-2.52
10 THHN	····· •		-4000	╞──┼	\$0.28	-\$1,100.00	0.014	-56.00
GFI RECEPTACLE			-14		\$12.70	-\$177.80	0.220	-3.08
						· · · · · · · · · · · · · · · · · · ·		
	· · · · · · · · · · · · · · · · · · ·							
		#705 00				+1 010 01		100 50
SUPERVISION & C		-\$785.03		MATE	RIALS	-\$1,912.06	M.H.	-139.56
MISC. SUPPLIES		-\$174.45					RATE	\$55.00
ABOR		7,675.80				LABOR		-\$7,675.80
	-\$	3,147.08		n			<i></i>	
MALL TOOLS	· · · · · · · · · · · · · · · · · · ·	-\$87.23		PKI(LE VOID A	FTER 30 DAY	rS	
MATERIALS		1,912.06		n				
SUBTOTAL		.3,781.64				TTACHED TE	RMS	
LO% PROFIT & OV	/ERHEAD			AND	CONDITI	ONS		
BOND								
				ACC	EPTED BY:			
ales Tax		EXEMPT	,					
				DAT	F:			
	TOTAL: -	\$13,782	1	DAI	L:			

IES COMMERCIAL, INC

4

DATE: **5/5/2025**

COR:

PR: **13**

AGCM PR REIVEW

06/04/2025 2:17:51 PM

DESCRIPTION		QTY	UNIT TYPE	MAT. UNIT	MAT. EXT.	LABOR UNIT	LABOR
THIS IS THE thing		600		0.96	(576.00)	0.122	EXT. (73.20)
THIS IS THE thing		-600 -28		0.98	(9.52)	-	(75.20)
THIS IS THE thing		-28		0.42	(21.00)	-	-
THIS IS THE thing		-60		0.25	(15.00)	-	-
THIS IS THE thing		-14		0.46	(6.44)	0.340	(4.76)
THIS IS THE thing		-14		0.45	(6.30)	0.180	(2.52)
THIS IS THE thing		-4000		0.275	(1,100.00)	0.014	(56.00)
THIS IS THE thing		-14		12.70	(177.80)	0.220	(3.08)
THIS IS THE thing		0		-	-	-	-
THIS IS THE thing		0		-	-	-	-
THIS IS THE thing		0		-	-	-	-
THIS IS THE thing		0		-	-	-	-
THIS IS THE thing		0		-	-	-	-
THIS IS THE thing		0		-	-	-	-
THIS IS THE thing		0		-	-	-	-
THIS IS THE thing		0		-	-	-	-
THIS IS THE thing		0		-	-	-	-
THIS IS THE thing		0		-	-	-	-
THIS IS THE thing		0		-	-	-	-
THIS IS THE thing		0		-	-	-	-
THIS IS THE thing		0		-	-	-	-
THIS IS THE thing		0		-	-	-	-
THIS IS THE thing		0		-	-	-	-
THIS IS THE thing		0		-	-	-	-
			MATERIALS	-	(1,912.06)	M.H.	(139.56)
SUPERVISION & COOR.	(689.82)	10%	off labor			RATE	\$ 48.33
MISC. SUPPLIES	(153.29)	22.22%	Off Supervisio	on		LABOR	(6,744.93
LABOR	(6,744.93)						
BURDEN	(2,765.42)		off labor				
SMALL TOOLS	(76.62)	1.136%	off labor				
MATERIALS	(1,912.06)						
ROUND UP / ROUND DOWN	-						n why Rate is \$ 48.33
SUBTOTAL	(12,342.14)	10%				and no	ot \$ 55.00?
10% PROFIT & OVERHEAD	(1,234.21)				_		
TOTAL	(13,576.35)			O REFLECT COS	TS		
				INCLUDED IN REQUSTS THA	- I		
				D TO THE TP			
			VETTED AN	NTAGES WERE D CONFRIMED 3) DIFFERENT			

PROPOSALS

Request for Information



La Vernia ISD 2023 Bond Projects (231091)			No. Printed	RFI00026 November 19, 2024	
Subject Detail/Drawing	Intermediate Science Ta	ables Power	Date	November 19, 2024	
To From	Braden Haley Alexander Ragland	Pfluger Architects, Inc BC General Contractors LLC	Status Response Due Resolved Date Cost Impact Schedule Impact	OPEN November 26, 2024 , Potentially Potentially	

Any recommendations offered by Bartlett Cocke are made in its capacity as a commercial builder and not as a design professional. Recommendations have not been vetted by a design professional and are offered only for purposes of constructability.

Attachments

Information Requested

Please clarify if the science room tables are to have outlets included per electrical drawing E3.1D. Currently the spec and details for the science classroom tables do not call out for any electrical inclusions.

Recommendation

Response Information

Responder

Response Date

Response

Science room tables are not intended to have electrical outlets. Disregard the 14 electrical outlets shown at ends of tables on sheet E3.1D.

-Braden Haley Pfluger Architects 1.28.2025



1 FLOOR PLAN - LEVEL 01 - SEG D - POWER 1/8" = 1'-0"

GENERAL NOTES - POWER

1. REFER TO SHEET E3.0P FOR POWER GENERAL NOTES.

KEYED NOTES

- E5. EQUIPMENT IN THIS ROOM SHALL BE INSTALLED IN ACCORDANCE WITH A COORDINATED CAD SHOP DRAWINGS OF ALL EQUIPMENT AND TRADES SUBMITTED AND APPROVED BY ENGINEER PRIOR TO ROUGH-IN.
- E6. PROVIDE NEMA 5-20R RECEPTACLE, HUBBELL 8310, BLACK, FOR CORRIDOR WITH MINIMUM #10 AWG CONDUCTOR.
- 120V, 20A, 2 #10 & 1 #10 GROUND IN 3/4" CONDUIT. VERIFY AND COORDINATE EXACT LOCATION AND HEIGHT WITH ACTUAL FOUNTAIN FURNISHED FOR THIS PROJECT PRIOR TO ROUGH-IN FOR RECEPTACLE TO BE HIDDEN BEHIND DRINKING FOUNTAIN LOWER REMOVABLE COVER. PROVIDE GFCI CIRCUIT BREAKER IN DESIGNATED PANEL FOR CIRCUIT AS INDICATED.


E12. CONNECT TO INDICATED CIRCUIT THRU MULTI-POLE CONTACTOR AND UTILITY CONTROLLER FOR EMERGENCY SHUT-OFF FOR THIS ROOM AND PROP ROOM. CONTACTOR ENCLOSURE SHALL BE INSTALLED ON WALL IN ABOVE CEILING AREA ABOVE THE RESPECTIVE PANELBOARD AT A COODINATED LOCATION. REFER TO

E22. PROVIDE CONNECTIONS FOR LAB UTILITY CONTROLLER AND SOLENOID VALVES WITH INDICATED CIRCUIT, 120V, 1PH, 20A, 2#12 & 1#12 GND IN 3/4" CONDUIT. COORDINATE CONTROL VOLTAGE FOR SOLENOIDS AND CONTRACTORS AS REQUIRED. REFER TO DIVISON 22 AND 23 FOR INSTALLATION REQUIREMENTS.


DIVISION 22 AND 23 FOR INSTALLATION REQUIREMENTS.

- E23. PROVIDE CONNECTIONS FOR ISIMET UTITLIY CABINET WITH INDICATED CIRCUIT, 120V, 1PH, 20A, 2 #12 & 1#12 GND IN 3/4" CONDUIT. REFER TO DIVISION 22 AND 23 PLANS AND SPECIFICATIONS FOR INSTALLATION REQUIREMENTS. COORDINATTE AND VERIFY EXACT LOCATION AND INSTALLATION REQUIREMENTS PRIOR TO ROUGH-IN.
- E24. PROVIDE EMERGENCY PANIC BUTTON FOR UITILITY CONTROL CABINET SHUT-DOWN. BUTTON SHALL BE PROVIDED WITH FACTORY FABRICATED CLEAR PLASTIC ENCLOSURE, HINGED AT THE TOP TO PERMIT LIFTING FOR ACCESS TO INITIATE AN ALARM. VERIFY EXACT LOCATION WITH ARCHITECT PRIOR TO ROUGH-IN.
- E36. PROVIDE RECESSED CLOCK-HANGER TYPE RECEPTACLE(S) AND STAINLESS STEEL DEVICE COVER PLATE(S) FOR WALL MOUNTED FLAT SCREEN TV MONITOR AS INDICATED COORDINATE EXACT ROUGH-IN LOCATION AND HEIGHT WITH TECHNOLOGY PLANS. ARCHITECTURAL PLANS AND ACTUAL MONITOR BEING FURNIHSED FOR THIS PROJECT PRIOR TO ROUGH-IN.
- E59. PROVIDE OUTLET AND CONNECTION FOR HVAC CONTROL PANEL AS REQUIRED, 120V, 20A, 2 #10 & 1 #10 GROUND IN 3/4" CONDUIT. VERIFY AND COORDINATE EXACT LOCATION(S), HEIGHT, QUANTITY OF PANELS AND ALL INSTALLATION REQUIREMENTS WITH HVAC CONTROL TRADES, INCLUDING MULTIPLE PANELS AT OTHER LOCATIONS SERVING SAME AREA. PROVIDE ADDITIONAL ROUGH-IN FOR DATA OUTLET IN PANEL FOR LAPTOP DATA CONNECTION AS WELL AS ROUGH-INS FOR HVAC CONTROL INSTALLATION REQUIREMENTS AND CABLING. CONTRACTOR IS RESPONSIBLE FOR PROVIDING BRANCH CIRCUIT TO ALL HVAC CONTROL PANELS AS INDICATED ON HVAC CONTROL TRADES COORDINATION DRAWINGS.
- E86. PROVIDE TEACHER STATION RECEPTACLE(S) AND TECHNOLOGY OUTLETS AS INDICATED. COORDINATE WITH TECHNOLOGY PLANS FOR OUTLET AND INSTALLATION REQUIREMENTS TO BE INSTALLED WITH IN 12 INCHES OF RECEPTACLE(S) PRIOR TO ROUGH-IN VERIFY MOUNTING HEIGHT AND EXACT LOCATIONS FOR ALL ROUGH-INS ALONG TEACHING WALL WITH ARCHTECTURAL DRAWINGS AND ARCHITECT AS REQUIRED.
- E128. PROVIDE CONNECTIONS AND TOGGLE DISCONNECT FOR ELECTRONIC TRAP PRIMER AS INDICATED, 120V/1PH, 20A, 2#12 & 1#12 GROUND IN 3/4" CONDUIT. COORDINATE INSTALLATION REQUIREMENTS WITH PLUMBING TRADES AND SURROUNDING AREA FOR EXACT LOCATIONS AS DIRECTED BY ARCHITECT.
- E136. PROVIDE NAC PANEL FED FROM INDICATED CIRCUIT WITH RED PAINTED AND LOCKABLE CIRCUIT BREAKER CLEARLY IDENTIFIED.
- E141. PROVIDE OUTLET, NEMA PLUG, AS APPLICABLE, AND CONNECTIONS FOR CLOTHES WASHER AS REQUIRED, 120V/1PH, 20A, 3 #10 & 1 #10 GROUND IN 3/4" CONDUIT. VERIFY AND COORDINATE NEMA CONFIGURATION WITH ACTUAL UNIT FURNISHED FOR THIS PROJECT. COORDINATE EXACT LOCATION WITH ARCHITECT AND OTHER TRADES PRIOR TO ROUGH-IN.
- E142. PROVIDE OUTLET, DISCONNECT SWITCH/NEMA PLUG, AS APPLICABLE, AND CONNECTIONS FOR COMMERICIAL ELECTRIC CLOTHES DRYER AS REQUIRED, 208V/1PH, 30A, 3 #8 & 1 #10 GROUND IN 3/4" CONDUIT. VERIFY AND COORDINATE NEMA CONFIGURATION WITH ACTUAL UNIT FURNISHED FOR THIS PROJECT. COORDINATE EXACT LOCATION WITH ARCHITECT AND OTHER TRADES PRIOR TO ROUGH-IN.
- E143. PROVIDE SCIENCE LAB RECEPTACLE(S) OUTLETS AS INDICATED. COORDINATE WITH ARCHITECTURAL PLANS FOR OUTLET AND INSTALLATION REQUIREMENTS. VERIFY MOUNTING HEIGHT AND EXACT LOCATION WITH ARCHITECTURAL DRAWINGS AND ARCHITECT AS REQUIRED.
- E151. REFER TO DEMO SHEET.

SEGMENT C SEGMENT D





ENLARGED - INTERMEDIATE SCHOOL - ELECTRICAL ROOM D117 2 1/4" = 1'-0"






E9. PROVIDE OUTLET AND CONNECTION FOR ELECTRIC DRINKING FOUNTAIN AS REQUIRED,







PR # 2 11 of 18



Proposal Request

PROJECT: (name and address) La Vernia ISD 2023 Bond 22-075

OWNER: (name and address) La Vernia ISD 13600 US Highway 87 W, La Vernia, TX 78121 **CONTRACT INFORMATION:** Contract For: General Construction Date:

ARCHITECT: (name and address) Pfluger Architects 200 E. Grayson, Ste. 115 San Antonio, Texas 78215 Architect's Project Number: 22075 Proposal Request Number: 09 Proposal Request Date: April 21, 2025

CONTRACTOR: *(name and address)* Bartlett Cocke General Contractors 8706 Lockway Street San Antonio, Texas 78217

The Owner requests an itemized proposal for changes to the Contract Sum and Contract Time for proposed modifications to the Contract Documents described herein. The Contractor shall submit this proposal within fourteen (14) days or notify the Architect in writing of the anticipated date of submission.

(Insert a detailed description of the proposed modifications to the Contract Documents and, if applicable, attach or reference specific exhibits.)

At the Junior High School:

- Delete 16 electric hand dryers (TA-8), with associated electrical supply, from the project.

- Add 16 Paper towel dispenser / waste receptacles (TA-9) to the project.

Applicable to the following rooms:

Women's Restroom L102 (2), Men's Restroom L103 (2), Girls TR M121.4 (2), Boys TR M119.5 (2), Girls TR M114 (2), Boys TR M113 (2), Girls TR M212 (2), Boys TR M211(2).

THIS IS NOT A CHANGE ORDER, A CONSTRUCTION CHANGE DIRECTIVE, OR A DIRECTION TO PROCEED WITH THE WORK DESCRIBED IN THE PROPOSED MODIFICATIONS.

REQUESTED BY THE ARCHITECT:

Braden Haley, AIA PRINTED NAME AND TITLE



1