

School Board Meeting:

April 23, 2018

Subject:

Bid Award - Buffalo High School Building Controls Replacement

Presenter:

**John Heltunen, Director
Buildings and Grounds**

SUGGESTED SCHOOL BOARD ACTION:

Accept the base bid from UHL Company, Inc. for \$532,575 to complete the replacement of Building HVAC controls.

Reject Alternate #1 to complete the replacement of variable speed drives for the hot water circulation system.

DESCRIPTION:

Attached is the bid tabulation for Buffalo High School Building Controls Replacement project showing the one company that placed a bid, along with a letter of recommendation from Hallberg Engineering to accept the base bid and reject Alternate #1.

The project scope is to eliminate the pneumatically actuated components that regulate HVAC equipment at the High School and replace them with digitally actuated components and wiring.

The Alternate #1 to replace the variable speed drives is a project that we can budget for in the future, but does not fit into this fiscal year's allocation.

If you have any questions about this project, please feel free to call me at 763-682-8773.