

# Memo

**To:** Board of Education  
**From:** David Nardone  
**CC:** Dr. Conway  
**Date:** 6/18/2021  
**Re:** Property Update

---

The following is an update on our school buildings:

## **Bradley**

We had a major hot water issue at Bradley. We were required to replace 3 hot water pumps and replace 4 check valves. The boilers and hot water heater were serviced and cleaned by in house personnel. The catalyst oil reduction device was installed we are seeing a 14% decrease in oil use.

## **Irving**

Responded to 2 boiler failures and restored heat without impact to classes.

## **Derby High School**

Installed 11 projectors.

## **Derby Middle School**

Installed various bulletin boards. Replaced filters in roof top units. 2 heat failures were repaired by OC.

## **District Wide**

Photo ID program rolled out.

Respectfully submitted by,

David M. Nardone, Facilities Manager