

MAINTENANCE REPORT

APRIL 2026

Submitted by: Reid Reagan

Maintenance staff has been busy with state inspections, assist Fire Marshal with fire inspections, Health and Human Services with kitchen inspections, Hartford Steam Boilers with the boiler inspections, and Asbestos inspection at all the schools and 2 Hutterite colonies. Also planted trees/bushes around the district for Earth Day.

BHS:

Assist in the setup/teardown of Prom decorations, hang lights in the gym and lobby, setup spot lights, red carpet at entrance. Replace faulty pressure relief valve, controls the boiler makeup water supply. Replace broken bleacher parts. Replace faulty circ pump at Sportsplex women's restroom. Install new track electronic timing system in the track timing shed. Repaint numbers, finish line on the all-weather track.

BMS:

Install new outlet in the library to serve flat-screen TV. Change out electric outlets in science lab, service restored. Recharge the cooler in the kitchen, service restored. Repair automatic doors (2) at the main office and the gymnasium entrance.

BULLSHOE-KWB wing:

Replace faulty shark bite fittings in the unit heaters (3) with solder joint pressure fittings.

BES:

Assist Setup/teardown for Early Head Start basketball games. Assist architectural and engineering staff in the design of the renovation/upgrade.

NAPI:

Replace faulty control board to Lochinvar modular boiler. Install new thermostat in the gym, diagnose loose electrical connection to the rooftop air handler, service restored. Install new sound proof doors (3) at the SPED rooms.

BABB:

Install new solenoid valve in the freezer, recharge the cooler in the kitchen, systems restored.

BULLSHOE-VC wing:

Locate utilities in the vacant lot east (Children's Garden) for the SAMHSA Native Connections: Culture and Hope program's expansion, moving in new modular trailers (3).