

Board of Education Information

To: Board of Education

From: Matt Rich

Date: January 21, 2026

Re: Approve Replacement of Winfield Central Fire Control Panel

Recommendation:

It is the recommendation of the Superintendent to approve replacement of the Winfield Central Fire Control Panel from Thompson Electronics Company at a cost of \$9,388.

Background Information:

Replacement of the Fire Control Panel at Winfield Central was identified as a need during the inspections this summer as we had several false triggers and replacement components were no longer available. As such, we added this project to the Illinois State Maintenance Grant Program. We have worked to take multiple bids for the replacement work and have identified Thompson Electronics Company to be the lowest cost replacement for the work that needs to be done.