

# FROM THE DESK OF CHARLES GIVINES

## June 2019 Buildings and Grounds Report

**Maya Angelou:** Replaced the galvanized pipe with copper in 3 rooms, and 3 restrooms, and the water fountains; repaired both boilers and repaired the water leaks and repaired the 2 exhaust fans on the 1<sup>st</sup> floor.

**Bryant School:** repaired the kitchen cabinet doors, repaired the kettles, repaired ceiling leaks and tiles, repaired fence, adjusted heat.

**Holmes School:** had to light the hot water tank, changed bulbs, repaired boilers, removed locks to rekey, replaced (2) motor in hot water pumps, repaired (2) heads on the toilets.

**Riley School:** repaired roof, and installed new exterior and interior camera's as well as installed new wall receptacles'.

**Field School:** boiler repairs.

**Sandburg School:** changed light ballast in hallway.

**Whittier School:** repaired roofing leaks and Ceiling tiles.

**Districtwide:** cleaned garage, took the bus in for repair, took courier van in for tires, trucks had oil changes, fixed faucets, picked up trucks from regional.

**Note: We Completed 32 Work Orders This Month.**