

MAINTENANCE REPORT NOVEMBER 2025

Submitted by: Reid Reagan

Maintenance staff has been busy making repairs resulting from the high winds, in addition to preparing for winter, winterizing outdoor restrooms, servicing snow removal equipment.

BHS:

Reattach blown off exhaust stacks on roof. Assist in the setup/teardown decorating for Sobriety Ball. Service the back-up generator.

WBH:

Repair damaged chain link fence, result of truck driving into it.

BES:

Reattach metal hand railing at the northeast side of school.

BULLSHOE-KWB:

Repair food warmer, wouldn't heat, replace faulty temperature control switch/relay. Service the back-up generator.

BULLSHOE-VC:

Replace construction fence with black vinyl coated chain link fence. Service the back-up generator.

NAPI:

Install snow fence on front lawn. Replace broken window in back hallway.

BABB:

Replace lights in bus garage. Replace faulty 3/4" domestic hot water line. Snake sewer line, system restored.

BUS GARAGE:

Repair, realign roll-up overhead doors (4), replace 1 broken panel. Service restored. Insulate tracks/rollers with weather stripping.