

APRIL 2018 BUILDINGS AND GROUNDS REPORT

We were able to do a pretty good clean-up of the schools this spring in preparation for the summer clean-up we prepared the staff for better way to do our summer clean-up.

Bryant: Repaired both boilers cleaned and replaced gaskets, installed new drives in boiler #2 and, replaced the controls on the booster pumps.

Sandburg: Installed booster pump to supply more pressure to the water on the west side of the building, installed new toilets in rm#101, 103 and dug a new pit in the crawl space to pump water out of the crawl space. Installed flushometers in the boys and girls restrooms. Replaced Filters, bulbs, and ceiling tiles.

Riley: Installed heating and air conditioning unit in the Superintendent's office, replace ballasts and bulbs in various classrooms and, hallways. Also changed unit filters.

Whittier: Replaced ceiling tiles and, repaired the hot water line in the boiler room.

Maya Angelou: Replaced ceiling tiles throughout the building and installed door closures and holders. Also repaired and replaced toilets on the primary section. Also replaced flush valves, light bulbs and ballasts.

Gwendolyn Brooks: Repaired door closures, changed locks, and changed ballasts in the girl's washroom.

Lowell Longfellow: Removed all Equipment and changed the locks, as well as boarded up the entire first floor.