



Complete and submit this form, along with any supplemental documentation, to the Office of the President by 5:00pm on the seventh day prior to the Board meeting.

Date of Board Meeting: February 15, 2022

Subject:

Approve the transfer of \$47,518.08 from the Plant Repair and Replacement Fund to cover the replacement of an estimated 280 linear feet (L.F.) of three inch copper water line at the Richmond Campus.

Recommendation:

Approve the transfer of \$47,518.08 from the Plant Repair and Replacement Fund to cover the replacement of an estimated 280 linear feet of three inch copper water line at the Richmond Campus.

Background and Rationale:

The 3" water line feeding the building has developed a number of pinhole leaks over the past few years. The leaks have been patched but in order to prevent additional leaks the line needs to be replaced. We are recommending moving forward with the price quote from HB Mechanical at a cost of \$47,518.08. A second quote of was received From Gowan Inc. at \$51,527.00

Cost and Budgetary Support: \$47,518.08

Transfer from the Plant Repair & Replacement Fund

Strategic Priority Alignment:

Student Success

Community Impact

Resource Optimization

Institutional Excellence

Resource Person(s):

Bryce D. Kocian, Vice President of Administrative Services
Mike Feyen, Director of Facilities Management
Philip Wuthrich, Director of Purchasing

Signatures:



Originator

2/2/22

Date



Cabinet-Level Supervisor

02/02/2022

Date

President's Approval:



President

2-3-22

Date