Dashir Management Services, Inc.

www.dashirmanagement.com

Lewiston Altura School District

Custodial / Maintenance Report November 2024

Personnel Information

We are currently fully staffed.

Training Conducted

Staff completed OSHA required safety training on Safety Data Sheets.

Inspections

IEA completed Mock OSHA inspection on November 8.

MMC completed annual required test on back flow valves at the high school and elementary school.

Progress on Projects

- Worked with MMC to complete a boiler clean and tune at the high school. Glycol was added to the boiler system to bring the percentage up to the proper level.
- Mi Energy, working with Solar Connections, decided to wait until spring to install the new service line and transformer at the elementary as the proper equipment will be available then.
- The outside concession stand and ground water connections to the athletic fields were winterized for the season.

Comments

November is here, and the sidewalk has arrived. We are gearing up for the winter weather and the winter sports season.

Respectfully Submitted,

Dan Buege Facility Manager