Facilities Work Progress Report for JH/HS

Board Report for Jan/Feb 22

| Work to Begin or in Progress | Description | Update |
|---|---|---|
| High school | Fixed principals and maintenance office heaters. | Done. Prairie State did this. Waiting on bill. |
| Boiler room | Fixed leaky motor number 2 on boiler. | Done. Prairie State did this. Waiting on bill. |
| All Jr/Sr high school | Plowed parking lot and shovel/salted sidewalks. | Done.1-17-22/1-27-22/2-2-22/2-3-22/2-4-22/2-5-22/2-7-22 |
| Steam Boiler | Drained water bowls. | Done.1-18-22/1-28-22/1-31-22/2-8-22 |
| Hot water boiler | Changed filter and added chemicals to pot feeter. | Done. |
| All Jr/Sr high school | Did are Co2 monthly inspection. | Done. |
| All Jr/Sr high school | Did are monthly fire extingusisher inspection. | Done. |
| All Jr/Sr high school | Did are monthly exit/emergency light inspection. | Done. |
| Elementary | Met with Pepsi. | Done. |
| Boiler room | Fixed leaky motor number 4 on boiler. | Done. Prairie State did this. Waiting on bill. |
| Pe office | Built shevles for pe office. | Done. |
| High school | Hung old clock on wall | Done. |
| Boil room | Put new filter in pot feeder also cleaned seals. | Done. |
| New Gym | Got new control box and receivers for scoreboard to make wireless. Scoreboards are wireless now. | Done. |
| Boys jr high restroom | Put new wax ring on tiolet and seals. | Done. |
| Boys jr high restroom | Fixed partion door. | Done. |
| Safety office | Hung hook for Larry. | Done. |
| All Jr/Sr high school | Checked all sewer man hole. Had to pull water through system because there was toilet paper sitting in pipes. | Done. |
| Room 443 | Hung tv bracket and tv for Kevin Cummins | Done. |
| Parking lot | Put markers a long parking blocks. | Done. |
| Outside stuff | Fixed tire on snow blower. | Done. |
| Room 343 | Put drain cleaner down drains. | Done. |
| Outside stuff | Helped dig out snow around white bus then clear spot for them. | Done. |
| New Gym | Set up 7th grade sectional in dome. | Done. |
| Outside stuff | Snow blowed 4/5ft drift in court yard. | Done. |
| New Gym | Cleaned gym/gym area from fridays 7th grade sectional. | Done. |
| Band Room | Move 3 file cabinets up to loft and brought 2 file cabinet from loft. | Done. |
| Bus Barn | Took two file cabinets and a wood shelf to bus barn. | Done. |
| Room 430 | Put 16 led light buld up in light fixture. | Done. |
| Boiler rooms/baseball concessions | Yearly inspection on back flows. | Done.Prairie State did this. Waiting on bill. |
| Junior high | Put 2 new heat exchagers in three RTUs. Some parts are covered under warranty. Labor is not. | Done. Prairie State did this. Waiting on bill. |
| Kitchen | Unloaded pallet of food for kitchen. | Done. |
| High school hallway | Took down art decorations that they put up for christmas. | Done. |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |

| | | |
|---|---|---|
| | | |