

**Manor Independent School District**  
**Board of Trustees Board Meeting Agenda Item**  
January 21, 2024

|                           |
|---------------------------|
| <b>CONSENT ITEM SHEET</b> |
|---------------------------|

**RE:** Consider and possible action regarding delivery method for the Fencing Security Project at Manor New Tech Middle School and Manor New Tech High School for construction services, including possible delegation of authority to Superintendent and/or designee to negotiate and execute an agreement.

**Supporting Documents:**

1. Architect Drawings (Stantec)
2. RFP as the guidance document for the scope of work

**District Goals: Goal 5**

FACILITIES & MAINTENANCE- By 2026, Manor ISD will proactively provide facilities to ensure 100% of scholars will have safe, well-maintained, environmentally sustainable, and community accessible facilities.

---

*Bottom of Form*

**Background Information:**

This item addresses the selection of a contractor for the Fencing Security Project at Manor New Tech Middle School and Manor New Tech High School. The administration intends to proceed with the project and recommends utilizing a Cooperative Purchase or Interlocal Agreement as the delivery method.

**Fiscal Implications:**

Not exceed \$1.4M

The funding will come from the interest earned on the 2019 Bond funds.

**Administrative Recommendation:**

Administration recommends that the Board approve the delivery method for this project to Cooperative Purchasing or Interlocal Agreement for construction services for the Fencing Security Project at Manor New Tech Middle School and Manor New Tech High School. Administration further recommends that the Board delegate authority to the Superintendent to negotiate and execute an agreement for the construction services.

Administration has received proposals from three contractors for the Fence Project. These proposals are currently being evaluated based on key criteria to determine the best vendor for the project. The contractors that have submitted proposals are Balfour Beatty, Noble Texas Builders, and Braun & Butler. The final vendor selection will be made based on a comprehensive review of the full scope of work, with a focus on aligning the project's requirements with cost efficiency.

**Proposed Motion:**

*"I move that the Board select Cooperative Purchase or Interlocal Agreement as the delivery method for construction services for the Fencing Security Project at Manor New Tech Middle School and Manor New Tech High as presented by Administration for this project and authorize the Superintendent to negotiate a contract from one of the three vendors that submitted proposals, and further authorize the Superintendent to execute a contract."*

---

Mr. Joe Mendez  
**Contact Person**

---

Dr. Robert Sormani  
**Approved by Superintendent**



**Stantec Architecture Inc.**  
1905 Aldrich St, Suite 300  
Austin TX 78723-3544  
Tel: (512) 867-6000  
Fax: (512) 867-6001

**ASI 01**

**To: Manor ISD**

**From:** Tanya Berry, Senior Project Manager

**Project:** Manor New Tech Fencing

**ASI#:** 01

**Date:** 10/09/2024

The work shall be carried out in accordance with the following supplemental instructions issued in accordance with the Contract Documents. Proceeding with the work in accordance with these instructions indicates your acknowledgment that there will be no change in the contract sum or contract time. If changes in the contract sum or contract time are warranted, the general contractor shall submit a change order request for review and approval prior to commencement of the work unless otherwise noted below.

**Description:**

**Civil Updates**

C001 Site Plan

- Optimized Gate Layout located at the northwest entrance to improve accessibility for fire truck and school bus to enter the parking lot.
- Revised fence at the northwest corner to tie it into the existing utility fence (around equipment) to restrict pedestrian access to space adjacent to property, between the new fence and the existing retaining wall.
- 8' tall fence will be used on the east side of the building due to 2' difference in elevation
- Chain linked fences removed from the project in place of the Fortefence (or approved equal), in response to city comments.
- 5' x 8' landings added for the pedestrian gates located on the East side of the project adjacent to Joyce Turner Drive to allow for accessible egress. Concrete to slope down from landing to top of curb.

C002 Fencing and Concrete details

- Chain linked fence detail removed
- ForteFence detail added
- 6" Type IV TXDOT Curb added for protective curb
  - Note: there should be at least a 6" of separation form back of curb to the fence

**Architecture Updates**

G101 life Safety Plan

- Updated note to clarify the intent of pedestrian egress at vehicular gates. Provide red "PUSH TO EXIT" egress button for pedestrian use. Gates shall release (fail safe) upon loss of power to allow for pedestrian egress.

End of ASI #1 Narrative



D

C


B



D


C

B



# ALL DETAILS ARE NOT TO SCALE

governed by the "Texas Engineering Practice Act". No warranty of any kind is made by TxDOT for any purpose whatsoever. Liability for the conversion of this standard to other formats or for incorrect results or damages resulting from its use.





**Stantec Architecture Inc.**  
1905 Aldrich Street, Suite 300  
Austin TX 78723-3544

## ADDENDUM

Project/File: 214001222  
Addendum No.: 01  
Date: 8/26/2024, issued 9/4/2024  
Project: Manor New Tech Security Fencing



This addendum is to be read with and constitutes part of the tender document. This addendum is generally separated into sections for convenience; however, all contractors, subcontractors, material suppliers and other involved parties shall be responsible for reading the entire addendum. Failure to list an item(s) in all affected sections of this addendum does not relieve any party affected from performing per instructions, provided the information is set forth one time anywhere in the Addendum.

### DETAILS OF THE ADDENDUM:

See below Architectural and Civil scope, respectively.

#### Architectural Scope

##### General Drawings:

###### 1. G101:

Notes added as requested by AHJ. Existing fire apparatus access roads labeled on plan.

##### Civil Drawings:

###### 1. C001:

Minimum clear drive widths dimensioned on plan to meet AHJ code requirements.

Regards,

**YsaBella Licciardi** NCARB  
Project Architect  
Phone: 206-494-5021  
Ysabella.licciardi@stantec.com



MANOR ISD

# MANOR NEW TECH SECURITY FENCING

**PROJECT TEAM:**

**OWNER**

MANOR INDEPENDENT SCHOOL DISTRICT  
10335 US HWY 290E  
MANOR, TX 78653  
TEL: (512) 278-4000

**ARCHITECT**

STANTEC  
1905 ALDRICH ST  
AUSTIN, TX 78723  
TEL: (512) 328-0011

**CIVIL ENGINEER**

STANTEC  
1905 ALDRICH ST  
AUSTIN, TX 78723  
TEL: (512) 328-0011

**ELECTRICAL ENGINEER**

STANTEC  
1905 ALDRICH ST  
AUSTIN, TX 78723  
TEL: (512) 328-0011

**TECHNOLOGY**


STANTEC  
1905 ALDRICH ST  
AUSTIN, TX 78723  
TEL: (512) 328-0011

D

C

B

G



EXISTING 1-STORY  
BRICK BUILDING  
(12'-0" APPROX.)

EXISTING 1-STORY  
BRICK BUILDING  
(12'-0" APPROX.)

PROPOSED  
FENCE, REF. CIVIL

EXISTING 2-STORY  
BRICK BUILDING  
(30'-0" APPROX.)

EXIT DISCHARGE PATH

EXISTING 1-STORY  
BRICK BUILDING  
(24'-0" APPROX.)

EXISTING 1-STORY  
BRICK BUILDING  
(24'-0" APPROX.)

EXISTING 3-STORY  
BRICK BUILDING  
(51'-0" APPROX.)

EXISTING 1-STORY  
BRICK BUILDING  
(20'-0" APPROX.)

EXISTING FENCE,  
REF. CIVIL

EXIT DISCHARGE PATH

EXIT DISCHARGE PATH

EXIT DISCHARGE PATH

2

2

1

1

2

2

2

1

2

2

2

1

3

4

4

6

3

1

1

2

14

2

14

3

1

1

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

4

14

12

14

2

2

2

2

2

2

2

2

2

2

2

2

2

2

2

2

2

2

2

2

2

2

2

2

2

2

2

2

2

2

2

2

4

2

4

2

4

2

4

2

4

2

4

2

4

2

4

2

4

2

4

2

4

2

4

2

4

2

4

2

4

2

4

2

4

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

14

2

2

2

1

1

2

2

2

1

1

2

2

2

1

1

2

2

2

1

1

2

2

2

1

1

2

2

2

1

1

2

2

2

1

1

2

2

2

1

1

2

2

2

1

1

2

2

2

1

1

2

2

2

1

1

2

2

2

1

1

2

2

2

1

1

2

2

2

1

1

2

2


2

1

1







POLYPROPYLENE FIBER  
 150 mm X 150 mm  
 (6" X 6" X W1.4 X W  
 OR ONE LAYER 10M  
 MORE THAN 450 mm  
 DIRECTIONS.  
 REINFORCEMENT SHALL  
 SLAB MID-DEPTH AND  
 MEANS OF BAR SUPP  
 STRENGTH AND NUME  
 DISPLACEMENT AND  
 PROPER POSITION DU  
 THE P.C. CONCRETE.  
 STEEL BE PLACED DI  
 OR SAND CUSHION L

**SECTION**


CITY OF AUSTIN  
 DEPARTMENT OF PUBLIC WORKS

*Bill Anderson* *7/16/16*  
 ADOPTED


THE ARCHITECT/ENGINEER  
 RESPONSIBILITY FOR APPROVAL  
 OF THIS STANDARD.

**ALL DETAILS ARE  
 NOT LE**

DISCLAIMER: The use of this standard is governed by the "Texas Engineering Practice Act". No warranty of any kind is made by TxDOT for any purpose whatsoever. TxDOT assumes no responsibility for the conversion of this standard to other formats or for incorrect results or damages resulting from its use.




TYPICAL CABLE AND POST ARRANGEMENT




Note: All concrete footings shall be crowned a minimum 1" above the existing ground.

CHAIN-LINK BARRIER FENCE (6 FT.)


Foundation designs shown are "minimums" for a 6 ft. fence. Taller fences may require larger foundation designs.



TYPICAL BOTTOM GATE HINGE



TYPICAL STRETCHER-BAR BAND



TERMINAL POST DETAIL


GENERAL NOTES

1. Items hereon shall conform to Item 550, "Chain Link Fence".
2. Typical installation plan may vary as shown elsewhere directed by the Engineer. Location of gates shown also may vary.
3. Gate-frame members shall be bolted, at frame corners, with four 1/2" bolts per joint.
4. All cable connections are to be made with two 3/8" cables.
5. All pull posts and end posts and their foundations shall be as approved by the Engineer. Location of gates shown also may vary.
6. All pull post shall be furnished with two stretcher bars.
7. One end of each turnbuckle may be attached directly to a clevis.
8. Concrete footings are to be crowned at the top to shed water.

| GATE (TYPES AND SIZES) |                  |
|------------------------|------------------|
| Single Inclusive       | Double Inclusive |
| Up to 6'               | Up to 12'        |
| Over 6' to 12'         | Over 12' to 26'  |
| Over 12' to 18'        | Over 26' to 36'  |
| Over 18'               | Over 36'         |

| GATE FRAME (WEIGHT)      |              | GATE POST (WEIGHT)       |              |
|--------------------------|--------------|--------------------------|--------------|
| SIZE                     | WT./LIN. FT. | SIZE                     | WT./LIN. FT. |
| 1 1/2" nom dia. or equal | 2.72 Lbs.    | 2 1/2" nom dia. or equal | 5.79 Lbs.    |
|                          |              | 3 1/2" nom dia. or equal | 9.11 Lbs.    |
|                          |              | 6" nom dia.              | 18.97 Lbs.   |
|                          |              | 8" nom dia.              | 24.70 Lbs.   |

"OPTIONAL" 3 WIRE 45° BARBED WIRE ARM  
Barbed wire arm related items shall conform to Item 550, "Chain Link Fence."



FABRIC & TENSION WIRE DETAIL, TOP & BOTTOM

Texas Department of Transportation

## CHAIN LINK


### CLF-1

|                 |             |
|-----------------|-------------|
| FILE: c1710.dgn | SHW: TxDOT  |
| © TxDOT 1996    | DATE: 08/03 |
| REVISIONS       | DATE:       |

D

C

B



(LA500DC) 12VDC RESIDENTIAL LIGHT COMMERCIAL LINEAR ACTUATOR

**LiftMaster**  
 LIFTMASTER (CHAMBERLAIN GROUP, INC.)  
 ENGINEERED SERVICES

300 WINDSOR DR.  
 DAYTON, OH 45424  
 PHONE: (937) 419-4519  
 FAX: (937) 419-7099

|                                |            |
|--------------------------------|------------|
| DRW. BY: B. MOFFETT            | REVISION:  |
| DATE: 07/12/019                | SCALE: NTS |
| TITLE: LA500DC LINEAR ACTUATOR |            |
| CAD FILE: -                    |            |

SHEET NO:  
**1/1**

# POWER DEVICES

|            |   |
|------------|---|
| <b>TV</b>  | TELEVISION/LED MONITOR. RF SIGNAL AND POWER OUTLET (JUNCTION BOX AND CONDUIT BY ELECTRICAL CONTRACTOR, DEVICES BY OTHERS). REFER TO DETAIL ON E500 SERIES DRAWINGS. |
| <b>TW1</b> | TEACHER'S WORK STATION. REFER TO DETAILS ON E500 SERIES DRAWINGS.   |
| <b>WSX</b> | WORK STATION OUTLET DETAIL. REFER TO DETAILS ON E500 SERIES DRAWINGS.   |
| <b>PR</b>  | CEILING MOUNTED VIDEO PROJECTOR STATION. REFER TO DETAIL ON DRAWING E500 SERIES DRAWINGS.   |

# TELECOM OUTLETS

|  |                               |
|--|-------------------------------|
|  | OUTLET                        |
|  | OUTLET, CEILING MOUNTED       |
|  | FURNITURE SYSTEMS OUTLET      |
|  | OUTLET, MOUNTED IN FLOOR BOX  |
|  | OUTLET, MOUNTED IN POKE THRU  |
|  | OUTLET, MOUNTED IN POWER POLE |

# TELECOM OUTLET TYPES

|  |  |
|--|--|
|  | # INDICATES QUANTITY OF DATA JACKS, PULLSTRING ALWAYS PROVIDED. WHERE NO QUANTITY IS NOTED, 2 DATA JACKS AND PULLSTRING. |
|  | MOUNTED 3" ABOVE COUNTER BACKSPLASH  |
|  | BLANK FACEPLATE, ROUGH-IN ONLY   |
|  | DIRECT CONNECTION TO PANEL   |
|  | PATIENT MONITORING   |
|  | PAY TELEPHONE  |
|  | RACEWAY MOUNTED  |
|  | WALL MOUNTED TELEPHONE HANDSET OUTLET  |
|  | WIRELESS ACCESS POINT CONNECTION   |

# FIRE ALARM

|             |                          |
|-------------|--------------------------|
| <b>FAA</b>  | FIRE ALARM ANNUCIATOR    |
| <b>FACP</b> | FIRE ALARM CONTROL PANEL |
| <b>DH</b>   | DOOR HOLDER              |

# WORK DEFINITION

|  |                                      |
|--|--------------------------------------|
|  | NEW WORK                             |
|  | EXISTING                             |
|  | REMOVE EXISTING                      |
|  | REMOVE EXISTING ELECTRICAL EQUIPMENT |
|  | FUTURE                               |
|  | TEMPORARY, AS NOTED                  |
|  | KEY NOTE                             |
|  | EQUIPMENT IDENTIFICATION             |

# CIRCUITS

|  |  |
|--|--|
|  | RACEWAY CONCEALED IN CEILING OR WALL. EXPOSED RACEWAY IS ALLOWED ONLY WHERE NOTED. |
|  | RACEWAY BELOW SLAB OR UNDERGROUND  |
|  | RACEWAY UP   |
|  | RACEWAY DOWN   |
|  | RACEWAY CONTINUATION   |
|  | RACEWAY STUB-OUT WITH BUSHING  |
|  | JUNCTION BOX, CEILING OR ABOVE CEILING MOUNTED                                     |
|  | JUNCTION BOX, WALL MOUNTED   |
|  | JUNCTION BOX, IN-GROUND  |
|  | PULL BOX   |

|  |  |
|--|--|
|  | EXIT SIGN, FILLED SIDES INDICATE ILLUMINATED ANNOTATION, ARROWS INDICATE DIRECTIONAL GRAPHICS              |
|  | WALL MOUNTED EXIT SIGN, FILLED SIDES INDICATE ILLUMINATED ANNOTATION, ARROWS INDICATE DIRECTIONAL GRAPHICS |
|  | EXIT SIGN WITH EMERGENCY BATTERY PACK  |
|  | WALL MOUNTED EXIT SIGN WITH EMERGENCY BATTERY PACK   |
|  | EMERGENCY BATTERY PACK, NUMBER OF LAMPS NOT INDICATED  |
|  | WALL MOUNTED EMERGENCY BATTERY PACK, NUMBER OF LAMPS NOT INDICATED   |
|  | EMERGENCY WITH REMOTE BATTERY PACK, NUMBER OF LAMPS NOT INDICATED  |
|  | WALL MOUNTED EMERGENCY WITH REMOTE BATTERY PACK, NUMBER OF LAMPS NOT INDICATED                             |
|  | RECESSED LINEAR WALL WASH LUMINAIRE, LENGTH TO SCALE   |
|  | LINEAR PENDANT MOUNTED WALL WASH LUMINAIRE, LENGTH TO SCALE  |
|  | RECESSED WALL WASH LUMINAIRE   |
|  | SURFACE MOUNTED WALL WASH LUMINAIRE  |
|  | PENDANT MOUNTED WALL WASH LUMINAIRE  |
|  | RECESSED ACCENT LUMINAIRE  |
|  | SURFACE MOUNTED ACCENT LUMINAIRE   |
|  | PENDANT MOUNTED ACCENT LUMINAIRE   |
|  | MONOPOINT LUMINAIRE  |
|  | TRACK LIGHTING   |
|  | CONTINUOUS SOURCE LUMINAIRE, PATH AS INDICATED   |
|  | MULTI-LAMP ACCENT LUMINAIRE, NUMBER OF LAMPS NOT INDICATED   |
|  | WALL MOUNTED MULTI-LAMP ACCENT LUMINAIRE, NUMBER OF LAMPS NOT INDICATED                                    |
|  | OVERCOUNTER TASK LUMINAIRE   |
|  | UNDERCABINET TASK LUMINAIRE  |
|  | FIBER OPTIC REMOTE SOURCE  |
|  | STEP LUMINAIRE   |
|  | ILLUMINATED SIGN   |
|  | WALL MOUNTED ILLUMINATED SIGN  |
|  | NIGHT LIGHT  |
|  | WALL MOUNTED STROBE LIGHT  |

# LIGHTING CONTROLS

|  |  |
|--|--|
|  | SINGLE POLE SWITCH   |
|  | INDICATES WIRELESS CONTROL LOWER-CASE LETTER(S) NEAR SWITCH DENOTE SWITCH LEG(S) |
|  | DOUBLE POLE SWITCH   |
|  | THREE-WAY SWITCH   |
|  | FOUR-WAY SWITCH  |
|  | DIMMER SWITCH  |
|  | KEY OPERATED SWITCH  |
|  | MOMENTARY CONTACT LOW VOLTAGE SWITCH   |
|  | OCCUPANCY SENSOR SWITCH  |
|  | OCCUPANCY SENSOR/DIMMER SWITCH   |
|  | SWITCH WITH PILOT LIGHT  |
|  | PHOTOCELL SWITCH   |
|  | TIMER SWITCH   |
|  | LOW VOLTAGE CONTROL STATION, # INDICATES STATION IDENTIFICATION                  |
|  | DIMMING SYSTEM CONTROL PANEL   |
|  | EMERGENCY LIGHTING CONTROL UNIT  |
|  | LIGHTING CONTROL PANEL   |
|  | OCCUPANCY SENSOR SWITCH, CEILING MOUNTED   |
|  | PHOTO SENSOR CONTROL   |
|  | PHOTO SENSOR CONTROL, CEILING MOUNTED  |
|  | RELAY  |
|  | LOW VOLTAGE TRANSFORMER  |

|  |   |
|--|---|
|  | RECEPTACLE, NEMA #  |
|  | RECEPTACLE, NEMA #, CEILING MOUNTED                         |
|  | COMBINATION RECEPTACLE, NEMA # AND 120V                     |
|  | FURNITURE SYSTEMS RECEPTACLE, 120V                          |
|  | INDICATES CONTROLLED  |
|  | INDICATES 15A   |
|  | INDICATES TWIST LOCK  |
|  | INDICATES MOUNTED 3" (75 MM) ABOVE COUNTER BACKSPLASH       |
|  | MULTI-SERVICE FLOOR BOX (RECEPTACLES/OUTLETS AS INDICATED)  |
|  | MULTI-SERVICE POKE THRU (RECEPTACLES/OUTLETS AS INDICATED)  |
|  | MULTI-SERVICE POWER POLE (RECEPTACLES/OUTLETS AS INDICATED) |
|  | MULTI-SERVICE ASSEMBLY (RECEPTACLES/OUTLETS AS INDICATED)   |
|  | CLOCK RECEPTACLE, 120V                                      |
|  | CORD DROP, 120V   |
|  | CEILING CORD DROP, 120V                                     |

# RECEPTACLE TYPES

|  |  |
|--|--|
|  | A ARC FAULT CIRCUIT INTERRUPTER                                  |
|  | ARC FAULT CIRCUIT INTERRUPTER AND TAMPER RESISTANT               |
|  | D DEDICATED CIRCUIT  |
|  | G GROUND FAULT CIRCUIT INTERRUPTER                               |
|  | GROUND FAULT CIRCUIT INTERRUPTER AND TAMPER RESISTANT            |
|  | IG ISOLATED GROUND   |
|  | S SURGE PROTECTOR  |
|  | T TAMPER RESISTANT   |
|  | U INTEGRAL USB PORT(S)   |
|  | WP GROUND FAULT CIRCUIT INTERRUPTER WITH WEATHER RESISTANT COVER |

# CONTROLS

|  |  |
|--|--|
|  | NON-FUSED SAFETY SWITCH  |
|  | FUSED SAFETY SWITCH, FUSE RATING INDICATED                               |
|  | COMBINATION MOTOR STARTER AND FUSED SAFETY SWITCH, FUSE RATING INDICATED |
|  | MOTOR STARTER  |
|  | MANUAL MOTOR STARTER   |
|  | AUTOMATIC DOOR PUSHPLATE   |
|  | DEAD FRONT GFCI  |
|  | EMERGENCY SHUTDOWN   |
|  | ENCLOSED CIRCUIT BREAKER   |
|  | ENCLOSED CONTACTOR   |
|  | PUSH BUTTON CONTROL STATION  |
|  | TOGGLE SWITCH, MOTOR RATED   |
|  | TOUCHLESS AUTOMATIC DOOR OPENER  |
|  | DIRECT DIGITAL CONTROL PANEL   |
|  | RELAY  |
|  | THERMOSTAT   |
|  | TIME CLOCK   |
|  | VARIABLE FREQUENCY DRIVE   |

# ELECTRICAL EQUIPMENT

|  |  |
|--|--|
|  | 208V OR 240V POWER PANELBOARD                          |
|  | 480V OR 600V POWER PANELBOARD                          |
|  | EQUIPMENT CABINET OR PANEL                             |
|  | EQUIPMENT CONNECTION. FILL INDICATES EMERGENCY CIRCUIT |
|  | GROUND BAR   |
|  | MOTOR CONNECTION, 1Ø                                   |
|  | MOTOR CONNECTION, 3Ø                                   |
|  | BUS DUCT   |
|  | AUTOMATIC TRANSFER SWITCH                              |
|  | BUS DUCT PLUG  |
|  | SPD SURGE PROTECTIVE DEVICE                            |
|  | T TRANSFORMER, NOT TO SCALE                            |
|  | T TRANSFORMER, DRAWN TO SCALE                          |

|              |                                       |          |
|--------------|---------------------------------------|----------|
| BC           | BONDING CONDUCTOR                     | MECH     |
| BCU          | BARE COPPER                           | MET      |
| BFC          | BELOW FINISHED CEILING                | MFR      |
| BFG          | BELOW FINISHED GRADE                  | MH       |
| BKR          | BREAKER                               | MIN      |
| BLDG         | BUILDING                              | MISC     |
| BOF          | BOTTOM OF FIXTURE                     | MLO      |
| BTM          | BOTTOM                                | MM       |
| C            | CONDUIT                               | MSB      |
| CW           | COMPLETE WITH                         | MTD      |
| CAP          | CAPACITY                              | MTG      |
| CATV         | CABLE ANTENNA TELEVISION              | MTS      |
| CB           | CIRCUIT BREAKER                       | MV       |
| CCTV         | CLOSED CIRCUIT TELEVISION             | MVCB     |
| CEC          | CANADIAN ELECTRIC CODE                | MW       |
| CFOI         | CONTRACTOR FURNISHED, OWNER INSTALLED | N        |
| CIRC         | CIRCULATING                           | NAC      |
| CKT          | CIRCUIT                               | NC       |
| CL           | CENTERLINE                            | NEC      |
| CLG          | CEILING                               | NEMA     |
| CM           | CEILING MOUNTED                       | NIC      |
| CMU          | CONCRETE MASONRY UNIT                 | NL       |
| CO           | CONDUIT ONLY                          | NO       |
| COMM         | COMMUNICATIONS                        | NTS      |
| CONC         | CONCRETE                              | OC       |
| CONN         | CONNECTION                            | OD       |
| CONST        | CONSTRUCTION                          | OFCI     |
| CONT         | CONTINUOUS                            | OFE      |
| CONTR        | CONTRACTOR                            | OH       |
| CPT          | CONTROL POWER TRANSFORMER             | OL       |
| CPU          | CENTRAL PROCESSING UNIT               | OS       |
| CR           | CRITICAL BRANCH                       | OSP      |
| CT           | CURRENT TRANSFORMERS                  | P        |
| CTR          | CENTER                                | PA       |
| CU           | COPPER                                | PB       |
| CUH          | CABINET UNIT HEATER                   | PD       |
| D            | DEDICATED                             | PF       |
| DC           | DIRECT CURRENT                        | PH       |
| DET          | DETAIL                                | PNL      |
| DIAM         | DIAMETER                              | POE      |
| DIM          | DIMENSION                             | POS      |
| DISC         | DISCONNECT                            | PR       |
| DIV          | DIVISION                              | PT       |
| DL           | DAMP LOCATION                         | PTS      |
| DN           | DOWN                                  | PTZ      |
| DP           | DISTRIBUTION PANEL                    | PV       |
| DPDT         | DOUBLE POLE, DOUBLE THROW             | PVC      |
| DPR          | DAMPER                                | PWR      |
| DPST         | DOUBLE POLE, SINGLE THROW             | R        |
| DWG          | DRAWING                               | RA       |
| DWH          | DOMESTIC WATER HEATER                 | REC      |
| EA           | EACH                                  | RECP     |
| EC           | ELECTRICAL CONTRACTOR                 | REQD     |
| EF           | EXHAUST FAN                           | REX      |
| ELEC         | ELECTRICAL                            | RM       |
| ELEV         | ELEVATOR                              | RNC      |
| EM           | EMERGENCY                             | RO       |
| EM GEN       | EMERGENCY GENERATOR                   | RSC, RGS |
| EMT          | ELECTRICAL METALLIC TUBING            | SCCR     |
| ENCL         | ENCLOSURE                             | SEC      |
| EP           | ELECTRIC-PNEUMATIC                    | SECT     |
| EPO          | EMERGENCY POWER OFF                   | SIM      |
| EQ           | EQUIPMENT BRANCH                      | SM       |
| EQUIP        | EQUIPMENT                             | SMR      |
| ERL          | EXISTING TO BE RELOCATED              | SPD      |
| ETD          | EMERGENCY TRANSFER DEVICE             | SPDT     |
| EWC          | ELECTRIC WATER COOLER                 | SPECS    |
| EXH          | EXHAUST                               | SPST     |
| EXIST, E, EX | EXISTING                              | SS       |
| EXP          | EXPLOSION PROOF                       | ST       |
| EXTER        | EXTERIOR                              | STD      |
| F&I          | FURNISHED AND INSTALLED               | SW       |
| FA           | FIRE ALARM                            | SWBD     |
| FAA          | FIRE ALARM ANNUCIATOR                 | SWGR     |
| FACP         | FIRE ALARM CONTROL PANEL              | SYS      |
| FB           | FLOOR BOX                             | TBB      |
| FCU          | FAN COIL UNIT                         | TC       |
| FLOOR        | FLOOR                                 | TE       |
| FLUOR        | FLUORESCENT                           | TELE     |
| FO           | FIBER (FIBRE) OPTIC                   | TELECOM  |
| FP           | FIRE PROTECTION                       | TEMP     |
| FS           | FUSIBLE SWITCH                        | TERM     |
| FSCS         | FIRE FIGHTER SMOKE CONTROL STATION    | TGB      |
| FU           | FUSE                                  | TMGB     |
| FVNR         | FULL VOLTAGE NON REVERSING            | TOF      |
| FVR          | FULL VOLTAGE REVERSING                | TP       |
| G, GND       | GROUND                                | TR       |
| GY           | GREEN YELLOW                          | TSP      |
| GA           | GAUGE                                 | TSTAT    |

D

C

B

D

1. WHENEVER USED IN THESE SPECIFICATIONS OR DRAWINGS, THE FOLLOWING TERMS SHALL HAVE THE INDICATED MEANINGS:
  - A. FURNISH: TO SUPPLY AND DELIVER TO THE PROJECT SITE, READY FOR UNLOADING, UNPACKING, ASSEMBLING, INSTALLING, AND SIMILAR OPERATIONS.
  - B. INSTALL: TO PERFORM ALL OPERATIONS AT THE PROJECT SITE, INCLUDING, BUT NOT LIMITED TO, AND AS REQUIRED: UNLOADING, UNPACKING, ASSEMBLING, ERECTING, PLACING, ANCHORING, APPLYING, WORKING TO DIMENSION, FINISHING, CURING, PROTECTING, CLEANING, TESTING, COMMISSIONING, STARTING UP AND SIMILAR OPERATIONS, COMPLETE, AND READY FOR THE INTENDED USE.
  - C. PROVIDE: TO FURNISH AND INSTALL COMPLETE, AND READY FOR THE INTENDED USE.
  - D. FURNISHED BY OWNER (OR OWNER-FURNISHED) OR FURNISHED BY OTHERS: AN ITEM FURNISHED BY THE OWNER OR UNDER OTHER DIVISIONS OR CONTRACTS, AND INSTALLED UNDER THE REQUIREMENTS OF THIS DIVISION, COMPLETE, AND READY FOR THE INTENDED USE, INCLUDING ALL ITEMS AND SERVICES INCIDENTAL TO THE WORK NECESSARY FOR PROPER INSTALLATION AND OPERATION. INCLUDE THE INSTALLATION UNDER THE WARRANTY REQUIRED BY THIS DIVISION.
  - E. ENGINEER: WHERE REFERENCED IN THIS DIVISION, "ENGINEER" IS THE ENGINEER OF RECORD AND THE DESIGN PROFESSIONAL FOR THE WORK UNDER THIS DIVISION, AND IS A CONSULTANT TO, AND AN AUTHORIZED REPRESENTATIVE OF, THE ARCHITECT, AS DEFINED IN THE GENERAL AND/OR SUPPLEMENTARY CONDITIONS. WHEN USED IN THIS DIVISION, IT MEANS INCREASED INVOLVEMENT BY, AND OBLIGATIONS TO, THE ENGINEER, IN ADDITION TO INVOLVEMENT BY, AND OBLIGATIONS TO, THE "ARCHITECT".
2. AHJ: THE LOCAL CODE AND/OR INSPECTION AGENCY, AUTHORITY HAVING JURISDICTION OVER THE WORK.
3. NRTL: NATIONALLY RECOGNIZED TESTING LABORATORY, AS DEFINED AND LISTED BY OSHA IN 29 CFR 1910.7 (E.G., UL, ETL, CSA), AND ACCEPTABLE TO THE AHJ OVER THIS PROJECT.
4. THE TERMS "EQUIVALENT", OR "EQUAL" ARE USED SYNONYMOUSLY AND SHALL MEAN "ACCEPTED BY OR ACCEPTABLE TO THE ENGINEER AS EQUIVALENT TO THE ITEM OR MANUFACTURER SPECIFIED", "EQUIVALENT" OR "EQUAL" PRODUCTS SHALL BE LABELED, LISTED, CERTIFIED, OR ALL THREE, BY AN NRTL, AND ACCEPTABLE TO THE AHJ OVER THIS PROJECT.

### 1-3 PRE-BID SITE VISIT

1. PERSONALLY INSPECT THE SITE OF THE PROPOSED WORK AND BECOME FULLY INFORMED OF CONDITIONS UNDER WHICH THE WORK IS TO BE DONE. FAILURE TO DO SO WILL NOT BE CONSIDERED SUFFICIENT JUSTIFICATION TO REQUEST OR OBTAIN EXTRA COMPENSATION OVER AND ABOVE THE CONTRACT PRICE.

### 1-4 MATERIAL AND WORKMANSHIP

1. PROVIDE ALL MATERIAL AND EQUIPMENT NEW AND IN FIRST CLASS CONDITION. PROVIDE MARKINGS OR A NAMEPLATE FOR ALL MATERIAL AND EQUIPMENT IDENTIFYING THE MANUFACTURER AND PROVIDING SUFFICIENT REFERENCE TO ESTABLISH QUALITY, SIZE AND CAPACITY. ALL WORKMANSHIP SHALL BE OF THE FINEST QUALITY, AS DEFINED BY THE MECHANICAL AND ELECTRICAL CODES, TRADE AND PRACTICE. PROVIDE THE EQUIPMENT WILL NOT BE ACCEPTABLE):
  - A. COMMERCIAL HEAVY DUTY GRADE
2. PROVIDE ALL HOISTS, SCAFFOLDS, STAGING, RUNWAYS, TOOLS, MACHINERY, AND EQUIPMENT REQUIRED FOR THE INSTALLATION AND PERFORMANCE OF THE ELECTRICAL WORK. STORE AND MAINTAIN MATERIAL AND EQUIPMENT IN CLEAN CONDITION, AND PROTECTED FROM WEATHER, MOISTURE, AND PHYSICAL DAMAGE.
3. FURNISH ONLY MATERIAL AND EQUIPMENT THAT ARE LISTED, LABELED, CERTIFIED, OR ALL THREE, BY A NATIONALLY RECOGNIZED TESTING LABORATORY, WHENEVER ANY LISTING OR LABELING EXISTS FOR THE TYPES OF MATERIAL AND EQUIPMENT SPECIFIED. AT A MINIMUM, GENERAL WORK PRACTICES FOR ELECTRICAL CONSTRUCTION SHALL BE IN ACCORDANCE WITH NECA 1 (LATEST EDITION), \* STANDARD PRACTICES FOR GOOD WORKMANSHIP IN ELECTRICAL CONSTRUCTION.

### 1-5 MANUFACTURERS

1. IN OTHER ARTICLES WHERE LISTS OF MANUFACTURERS ARE INTRODUCED, SUBJECT TO COMPLIANCE WITH REQUIREMENTS, PROVIDE PRODUCTS BY ONE OF THE MANUFACTURERS SPECIFIED.
2. WHERE MANUFACTURERS ARE NOT LISTED, PROVIDE PRODUCTS SUBJECT TO COMPLIANCE WITH REQUIREMENTS FROM MANUFACTURERS THAT HAVE BEEN ACTIVELY INVOLVED IN MANUFACTURING THE SPECIFIED PRODUCT FOR NO LESS THAN 5 YEARS.

### 1-6 COORDINATION

1. COORDINATE ALL WORK WITH OTHER DIVISIONS AND TRADES SO THAT VARIOUS COMPONENTS OF THE ELECTRICAL SYSTEMS ARE INSTALLED AT THE PROPER TIME, FIT THE AVAILABLE SPACE, AND ALLOW PROPER SERVICE ACCESS TO ALL EQUIPMENT. REFER TO ALL DRAWINGS, INCLUDING, BUT NOT LIMITED TO CIVIL, ARCHITECTURAL, STRUCTURAL, MECHANICAL, PLUMBING AND TO RELEVANT EQUIPMENT SUBMITTALS AND SHOP DRAWINGS TO DETERMINE THE EXTENT OF CLEAR SPACES. MAKE ALL OFFSETS REQUIRED TO CLEAR EQUIPMENT, BEAMS AND OTHER STRUCTURAL MEMBERS, AND TO FACILITATE CONCEALING RACEWAYS IN THE MANNER ANTICIPATED IN THE DESIGN. PROVIDE MATERIALS WITH TRIM THAT WILL FIT PROPERLY THE TYPES OF CEILING, WALL, OR FLOOR FINISHES ACTUALLY INSTALLED.

### 1-7 ORDINANCES, CODES, AND CLIENT

1. COMPLY WITH NATIONAL FIRE PROTECTION ASSOCIATION (NFPA) STANDARDS, STATE AND LOCAL BUILDING CODES, AND ALL OTHER APPLICABLE CODES AND ORDINANCES FOR PERFORMANCE, WORKMANSHIP, EQUIPMENT, AND MATERIALS. ADDITIONALLY, COMPLY WITH RULES AND REGULATIONS OF PUBLIC UTILITIES AND MUNICIPAL DEPARTMENTS AFFECTED BY CONNECTION OF SERVICES.
2. WHERE CONFLICTS BETWEEN VARIOUS CODES, ORDINANCES, RULES, AND REGULATIONS EXIST, COMPLY WITH THE MOST STRINGENT. WHEREVER REQUIREMENTS OF THESE SPECIFICATIONS, DRAWINGS, OR BOTH EXCEED THOSE OF THE ABOVE ITEMS, THE REQUIREMENTS OF THESE SPECIFICATIONS, DRAWINGS, OR BOTH SHALL GOVERN, CODE COMPLIANCE TO A MINIMUM IS MANDATORY. NOTHING IN THESE SPECIFICATIONS OR DRAWINGS SHALL BE DEEMED TO CONFLICT WITH THE CODES.
3. PROVIDE AND MAINTAIN ALL NECESSARY SIGNAL LIGHTS AND GUARDS FOR THE SAFETY OF THE PUBLIC.

C

B

CONTRACTOR FROM RESPONSIBILITY IN DIMENSIONS, DETAILS, SIZE OF MEMBERS, QUANTITIES; OR FOR OMITTING COMPONENTS OR FITTINGS; OR FOR NOT COORDINATING ITEMS WITH ARCHITECT BUILDING CONDITIONS.

## 1-10 ELECTRONIC DRAWING FILES

1. ELECTRONIC FILES FOR AS-BUILT COMPLETION CAN BE PROVIDED TO CONTRACTORS UPON REQUEST.

## 1-11 TRAINING

1. AT A TIME MUTUALLY AGREED UPON BETWEEN THE OWNER AND CONTRACTOR, TRAIN OWNER'S DESIGNATED PERSONNEL ON THE OPERATION AND MAINTENANCE OF THE EQUIPMENT PROVIDED FOR THIS PROJECT.
2. PROVIDE TRAINING TO INCLUDE BUT NOT BE LIMITED TO AN OVERVIEW OF THE SYSTEM AND/OR EQUIPMENT AS IT RELATES TO THE FACILITY AS A WHOLE; OPERATION AND MAINTENANCE PROCEDURES AND SCHEDULES RELATED TO STARTUP AND SHUTDOWN, TROUBLESHOOTING, SERVICING, PREVENTIVE MAINTENANCE AND APPROPRIATE OPERATOR INTERVENTION; AND REVIEW OF DATA INCLUDED IN THE OPERATION AND MAINTENANCE INSTRUCTIONS.
3. SCHEDULE TRAINING WITH OWNER WITH AT LEAST 7 DAYS IN ADVANCE NOTICE.

## 1-12 WARRANTIES

1. WARRANT EACH SYSTEM AND EACH ELEMENT THEREOF AGAINST ALL DEFECTS DUE TO FAULTY WORKMANSHIP, INSTALLATION, PRODUCT DESIGN OR MATERIAL FOR A PERIOD OF 12 MONTHS FROM THE DATE OF SUBSTANTIAL COMPLETION, UNLESS SPECIFIC ITEMS ARE NOTED TO CARRY A LONGER WARRANTY. THE CONSTRUCTION DOCUMENTS OR MANUFACTURER'S STANDARD WARRANTY EXCEEDS THE WARRANTY PERIOD(S), AS STATED IN THE GENERAL CONDITIONS.
2. ALSO WARRANT THE FOLLOWING ADDITIONAL ITEMS:
  - A. ALL RACEWAYS ARE FREE FROM OBSTRUCTIONS, HOLES, CRUSHING, OR BREAKS OF ANY KIND.
  - B. ALL RACEWAY SEALS ARE EFFECTIVE.
  - C. THE ENTIRE ELECTRICAL SYSTEM IS FREE FROM ALL SHORT CIRCUITS AND UNWANTED OPEN CIRCUITS AND GROUNDS.
3. THE ABOVE WARRANTIES SHALL INCLUDE LABOR AND MATERIAL. MAKE REPAIRS OR REPLACE DEFECTIVE MATERIAL WITHOUT ANY ADDITIONAL COSTS TO THE OWNER.
4. PERFORM THE REMEDIAL WORK PROMPTLY, UPON WRITTEN NOTICE FROM THE ENGINEER OR OWNER.
5. AT THE TIME OF SUBSTANTIAL COMPLETION, DELIVER TO THE OWNER ALL WARRANTIES, IN FULLY EXECUTED, INCLUDING TERM LIMITS FOR WARRANTIES EXTENDING BEYOND THE PERIOD EACH WARRANTY INSTRUMENT BEING ADDRESSED TO THE OWNER AND STARTING FROM THE COMMENCEMENT DATE AND TERM.

## 1-13 MISCELLANEOUS REMODELING WORK

1. PROVIDE ALL DEMOLITION OF EXISTING ELECTRICAL SYSTEMS AND NEW ELECTRICAL SYSTEMS REQUIRED BECAUSE OF BUILDING REMODELING. AS NOTED ON THE DRAWINGS, OR NECESSARY FOR PROPER OPERATION AND NEW CONSTRUCTION, REMOVE ALL ABANDONED CABLES AND WIRING ABOVE ACCESSIBLE CEILINGS AND VENTILATION SHAFTS.
2. EXERCISE EXTREME CAUTION IN THE INSTALLATION OF THIS WORK TO AVOID AN ELECTRICAL ACCIDENT. THE FACILITY IS EXISTING AND MAY REMAIN IN OPERATION DURING THIS WORK. COORDINATE ALL WORK SCHEDULES WITH THE BUILDING MANAGEMENT PRIOR TO DE-ENERGIZING ANY ELECTRICAL CIRCUITS TO AVOID CONFLICTS WITH ANY OTHER TENANT'S OPERATION. ALLOW 3 DAYS PRIOR CONFIRMED NOTIFICATION.
3. VERIFY THAT NEW AND EXISTING TO REMAIN INSTALLATIONS ARE CODE COMPLIANT, AND MAKE CORRECTIONS AS REQUIRED.
4. DEVELOP AND MAINTAIN A SET OF "RED-LINE AS-BUILT" DRAWINGS. THESE DRAWINGS SHALL BE MAINTAINED AT THE PROJECT CONSTRUCTION SITE AND AVAILABLE TO THE ENGINEER UPON REQUEST. THEY SHALL BE CURRENT AND SHALL REFLECT ALL ACTUAL ASPECTS OF THE ELECTRICAL INSTALLATION WHICH DEVIATED FROM THE PRESENT ELECTRICAL DESIGN DRAWINGS. THESE DRAWINGS SHALL BE SUBMITTED TO THE ENGINEER WITHIN 10 DAYS OF SUBSTANTIAL COMPLETION OF THE WORK AND MUST INCLUDE ALL PUNCH LIST ITEMS.
5. VERIFY THE LOADING OF EACH CIRCUIT AFFECTED BY THE REMODELING. DO NOT LOAD CIRCUITS TO MORE THAN 80% OF THEIR RATING.
6. PROVIDE UPDATED, TYPED DIRECTORY FOR EACH PANELBOARD BEING USED OR MODIFIED UNDER THIS CONTRACT. DESIGNATE NEW CIRCUITS AND AREA BEING SERVED.
7. FLEXIBLE STEEL CONDUIT SHALL BE USED TO WIRE ALL LIGHT FIXTURES AND VIBRATING EQUIPMENT IN LENGTHS FROM 18 INCHES TO 72 INCHES ONLY.
8. CONDUIT AND CABLE ABOVE CEILING SHALL BE SUPPORTED BY A UNISTRUT AND ALL THREE TRAPEZE. EACH PIECE OF CONDUIT SHALL BE SECURED TO THE TRAPEZE WITH A CONDUIT STRAP. THE TRAPEZE SUPPORTS SHALL BE INSTALLED PER CODE PLUS A MINIMUM OF 12" ABOVE THE CEILING.
9. NO CHANGE ORDER SHALL BE ISSUED DURING CONSTRUCTION FOR CHANGES DUE TO INCOMPATIBILITY. NO CHANGES SHALL BE MADE TO THE CIRCUITING SHOWN WITHOUT PRIOR WRITTEN APPROVAL OF THE ENGINEER OF RECORD. CIRCUIT NUMBERS SHALL BE INDICATED ON EACH JUNCTION BOX.
10. AT THE TIME OF FINAL PUNCH LIST, AN ELECTRICIAN MAY BE REQUIRED TO ASSIST IN THE REMOVAL OF PANEL COVERS, JUNCTION BOX COVERS, RECEPTACLES, SWITCHES, AND OTHER ELECTRICAL DEVICES.

## PART 2 ELECTRICAL WORK 2-1 BUILDING OPERATION



4. USE INSULATED, GROUNDING, OR COMBINATION BUSHINGS WHEREVER CONNECTION IS SUBJECT TO VIBRATION OR MOISTURE, WHEN REQUIRED BY NFPA 70, OR BOTH.

5. INSTALL PLASTIC BUSHINGS ON THE CONNECTIONS OF ALL REUSED CONDUIT.

#### 4-1-4 CONDUCTORS AND CABLES

1. ALL FEEDER AND BRANCH CIRCUIT CONDUCTORS NO. 12 AWG AND LARGER: STRANDED, TYPE THHN-2 OR XHHW-2 INSULATION.
2. ALL BRANCH CIRCUIT WIRING: SHALL NOT BE NOT SMALLER THAN NO. 12 AWG. IF NO CONDUCTOR SIZE IS INDICATED ON THE DRAWINGS FOR A BRANCH CIRCUIT, PROVIDE CONDUCTORS AND CONDUIT SIZED PER NFPA 70 AND BASED ON THE INDICATED BRANCH CIRCUIT OVERCURRENT PROTECTIVE DEVICE (OCPD) RATING AND NUMBER OF POLES. WHERE NO CIRCUIT SIZE (I.E., CONDUCTORS AND OCPD) IS INDICATED ON THE DRAWINGS FOR A BRANCH CIRCUIT, PROVIDE THREE NO. 12 AWG CONDUCTORS, IN 3/4-INCH RACEWAY, AND A 20A CIRCUIT BREAKER.
3. CONDUCTORS FIELD-INSTALLED WITHIN LIGHT FIXTURE CHANNELS: TYPE THHN.
4. CONTROL WIRING: STRANDED COPPER CONDUCTORS, 600V INSULATION, OF THE PROPER TYPE, SIZE AND NUMBER AS REQUIRED TO ACCOMPLISH SPECIFIED FUNCTION. MINIMUM SIZE: NO. 14 AWG, UNLESS NOTED OTHERWISE.
5. CONDUCTOR MATERIAL:
  - A. ANNEALED (SOFT) COPPER COMPLYING WITH ICEA S-95-658/NEMA WC70; SOLID CONDUCTOR FOR NO. 12 AWG AND SMALLER; CONCENTRIC, COMPRESSED-STRANDED FOR NO. 10 AWG AND LARGER.
  - B. CONDUCTOR INSULATION TYPES: 90-DEGREE C-RATED, TYPE THHN/THWN-2 OR XHHW-2 COMPLYING WITH ICEA S-95-658/NEMA WC70, UNLESS NOTED OTHERWISE IN THE DRAWINGS.
  - C. SIZES OF CONDUCTORS AND CABLES INDICATED OR SPECIFIED ARE IN AMERICAN WIRE GAGE (AWG - BROWN AND SHARPE).
  - D. UNLESS INDICATED OTHERWISE, SPECIAL PURPOSE CONDUCTORS AND CABLES, SUCH AS LOW VOLTAGE 4. CONTROL AND SHIELDED INSTRUMENT WIRING, SHALL BE AS RECOMMENDED BY THE SYSTEM EQUIPMENT MANUFACTURER.

#### 4-1-5 INSTALLATION OF CONDUCTORS AND CABLES

1. INSTALL ALL WIRING IN APPROVED RACEWAY AND ENCLOSURES, EXCEPT WHERE SPECIFIED OR INDICATED OTHERWISE.
2. SUPPORT ALL CONDUCTORS AND CABLES IN VERTICAL INSTALLATIONS, AS REQUIRED BY NFPA 70, BY INSTALLING CABLE SUPPORTS OR PLUG-TYPE CONDUIT RISER SUPPORTS OR WIRE-MESH SAFETY GRIPS.
3. INSTALL ALL CONDUCTORS AND CABLE IN CONTINUOUS RACEWAY WITHOUT TAPS OR SPLICES. SPLICE OR TAP ONLY IN APPROVED BOXES AND ENCLOSURES WITH APPROVED SOLDERLESS CONNECTORS; OR CRIMP CONNECTORS AND TERMINAL BLOCKS FOR CONTROL WIRING, AND; KEEP TO THE MINIMUM REQUIRED. INSULATE ALL SPLICES, TAPS AND JOINTS AS REQUIRED BY CODES.
4. ALL MATERIALS USED TO TERMINATE, SPLICE OR TAP CONDUCTORS: DESIGNED PROPERLY SIZED AND UL-LISTED FOR THE SPECIFIC APPLICATION AND CONDUCTORS INVOLVED. INSTALL IN STRICT ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS, USING THE MANUFACTURER'S RECOMMENDED TOOLS.
5. WHERE WIRING IS INDICATED AS INSTALLED, BUT THE CONNECTION IS INDICATED "FUTURE" OR "BY OTHERS" DIVISION, TRADE, OR CONTRACT; LEAVE A MINIMUM 3-FOOT "PIGTAIL" AT THE BOX, TAPE THE ENDS OF THE CONDUCTORS AND COVER THE BOX. IN GENERAL, BRANCH CIRCUIT "HOME RUN" ROUTING IS INDICATED ON THE DRAWINGS. COMPLETE WITH CIRCUIT NUMBERS AND PANELBOARD DESIGNATION. CONTINUE ALL SUCH "HOME RUN" WIRING TO THE DESIGNATED PANELBOARD, AS THOUGH "CIRCUIT RUNS" WERE INDICATED IN THEIR ENTIRETY.
6. WHEN MULTIPLE HOME RUNS ARE COMBINED INTO A SINGLE RACEWAY SUCH THAT THE NUMBER OF CONDUCTORS EXCEEDS FOUR (CONDUCTOR COUNT IS MADE UP OF ANY COMBINATION OF PHASE AND NEUTRAL CONDUCTORS), THE FOLLOWING RESTRICTIONS APPLY, WHICH ARE IN ADDITION TO THOSE IN NFPA 70:
  7. EMERGENCY POWER CIRCUITS - INCLUDES ALL CIRCUITS COVERED UNDER ARTICLES 700, 701 AND 702:
    - A. MAXIMUM OF 16 CONDUCTORS IN A SINGLE RACEWAY. FOR UP TO EIGHT CONDUCTORS IN A RACEWAY, A MINIMUM RACEWAY SIZE: 3/4-INCH. FOR GREATER THAN EIGHT CONDUCTORS, MINIMUM RACEWAY SIZE: 1-INCH. DO NOT INSTALL ANY OTHER TYPE OF CIRCUIT IN THIS RACEWAY.
    - B. THE MINIMUM WIRE SIZE FOR ALL CONDUCTORS IN THIS RACEWAY: NO. 10 AWG.
    - C. ONLY 15A AND 20A BRANCH CIRCUIT HOMERUNS MAY BE COMBINED INTO ONE RACEWAY.
8. GFCI CIRCUITS:
  - A. DO NOT USE MULTI-CONDUCTOR CIRCUITS, WITH A SHARED NEUTRAL, FOR ANY GFCI CIRCUIT BREAKER OR RECEPTACLE CIRCUIT.
  - B. FOR BRANCH CIRCUITS FED FROM GFCI CIRCUIT BREAKERS, LIMIT THE ONE-WAY CONDUCTOR LENGTH TO 100 FEET BETWEEN THE PANELBOARD AND THE MOST REMOTE RECEPTACLE OR LOAD ON THE GFCI CIRCUIT.
9. WIRING SHALL HAVE INSULATION OF THE PROPER COLOR TO MATCH COLOR CODE SYSTEM IN THE TABLE BELOW. ALL CONDUCTORS AND CABLES NOT PROPERLY COLOR CODED SHALL BE REMOVED AND REPLACED AT THE CONTRACTORS EXPENSE. CONDUCTORS SHALL HAVE CONTINUOUS COLOR CODED OUTER JACKET. IN LARGER SIZES, WHERE PROPERLY COLORED INSULATION IS NOT AVAILABLE, USE VINYL PLASTIC ELECTRICAL TAPE OF THE APPROPRIATE COLOR AROUND EACH CONDUCTOR AT ALL TERMINATION POINTS, JUNCTION AND PULL BOXES.
10. WIRING SHALL HAVE INSULATION OF THE PROPER COLOR TO MATCH COLOR CODE SYSTEM IN THE TABLE BELOW. ALL CONDUCTORS AND CABLES NOT PROPERLY COLOR CODED SHALL BE REMOVED AND REPLACED AT THE CONTRACTORS EXPENSE. CONDUCTORS SHALL HAVE CONTINUOUS COLOR CODED OUTER JACKET. IN LARGER SIZES, WHERE PROPERLY COLORED INSULATION IS NOT AVAILABLE, USE VINYL PLASTIC ELECTRICAL TAPE OF THE APPROPRIATE COLOR AROUND EACH CONDUCTOR AT ALL TERMINATION POINTS, JUNCTION AND PULL BOXES.
11. REFERENCE DETAIL FOR SYSTEM VOLTAGE:

| System Voltage | Conductor Type | Color |
|----------------|----------------|-------|
|----------------|----------------|-------|

D

C

B




D

C

B

WATER TRENCH

TO BE BUILT





S  
D  
M  
H

D

C


B






FRONT VIEW

CARD READER AND INTERCOM BOX DETAIL



FRONT VIEW

LOWER CARD READER AND INTERCOM BOX DETAIL




SECURITY PEDESTAL ELEVATION

GENERAL NOTES:

1. UNLESS OTHERWISE NOTED, ALL FASTENERS, SCREWS, BOLTS/ANCHORS AND OTHER MOUNTING ACCESSORIES SHALL BE MADE OF 316 STAINLESS STEEL.

**1** T501 NTS **TYPICAL CARD READER PEDESTAL DETAIL**




SECURITY PEDESTAL ELEVATION



GENERAL NOTES:

1. UNLESS OTHERWISE NOTED, ALL FASTENERS, SCREWS, BOLTS/ANCHORS AND OTHER MOUNTING ACCESSORIES SHALL BE MADE OF 316 STAINLESS STEEL.



**2** T501 NTS **TYPICAL CARD READER/INTERCOM PEDESTAL DETAIL**



**3** T501 NTS **CARD READER/INTERCOM PEDESTAL DETAIL**



**4** T501 NTS **CARD READER PEDESTAL DETAIL**





MANOR ISD

# MANOR NEW TECH SECURITY FENCING

**PROJECT TEAM:**

**OWNER**

MANOR INDEPENDENT SCHOOL DISTRICT  
10335 US HWY 290E  
MANOR, TX 78653  
TEL: (512) 278-4000

**ARCHITECT**

STANTEC  
1905 ALDRICH ST  
AUSTIN, TX 78723  
TEL: (512) 328-0011

**CIVIL ENGINEER**

STANTEC  
1905 ALDRICH ST  
AUSTIN, TX 78723  
TEL: (512) 328-0011

**ELECTRICAL ENGINEER**

STANTEC  
1905 ALDRICH ST  
AUSTIN, TX 78723  
TEL: (512) 328-0011

**TECHNOLOGY**


STANTEC  
1905 ALDRICH ST  
AUSTIN, TX 78723  
TEL: (512) 328-0011

D


C

B

F  
O  
M  
G  
G







POLYPROPYLENE FIBER  
 150 mm X 150 mm  
 (6" X 6" X W1.4 X W  
 OR ONE LAYER 10M  
 MORE THAN 450 mm  
 DIRECTIONS.  
 REINFORCEMENT SHALL  
 SLAB MID-DEPTH AND  
 MEANS OF BAR SUPP  
 STRENGTH AND NUME  
 DISPLACEMENT AND  
 PROPER POSITION DU  
 THE P.C. CONCRETE,  
 STEEL BE PLACED O  
 OR SAND CUSHION L

SECTION


CITY OF AUSTIN  
 DEPARTMENT OF PUBLIC WORKS

*Bill Anderson* 3/6/08  
 ADOPTED


THE ARCHITECT/ENGINEER  
 RESPONSIBILITY FOR APPROVAL  
 OF THIS STANDARD.

ALL DETAILS ARE  
 NOT LE

DISCLAIMER: The use of this standard is governed by the "Texas Engineering Practice Act". No warranty of any kind is made by TxDOT for any purpose whatsoever. TxDOT assumes no responsibility for the conversion of this standard to other formats or for incorrect results or damages resulting from its use.




TYPICAL CABLE AND POST ARRANGEMENT




Note: All concrete footings shall be crowned a minimum 1" above the existing ground.

CHAIN-LINK BARRIER FENCE (6 FT.)


Foundation designs shown are "minimums" for a 6 ft. fence. Taller fences may require larger foundation designs.



TYPICAL BOTTOM GATE HINGE



TYPICAL STRETCHER-BAR BAND



TERMINAL POST DETAIL


| GATE (TYPES AND SIZES) |                  |
|------------------------|------------------|
| Single Inclusive       | Double Inclusive |
| Up to 6'               | Up to 12'        |
| Over 6' to 12'         | Over 12' to 26'  |
| Over 12' to 18'        | Over 26' to 36'  |
| Over 18'               | Over 36'         |

| GATE FRAME (WEIGHT) |                    | GATE POST (WEIGHT) |                    |
|---------------------|--------------------|--------------------|--------------------|
| SIZE                | WT./LIN. FT.       | SIZE               | WT./LIN. FT.       |
| 1 1/2" nom dia.     | 2.72 Lbs. or equal | 2 1/2" nom dia.    | 5.79 Lbs. or equal |
|                     |                    | 3 1/2" nom dia.    | 9.11 Lbs. or equal |
|                     |                    | 6" nom dia.        | 18.97 Lbs.         |
|                     |                    | 8" nom dia.        | 24.70 Lbs.         |



OPTIONAL 3 WIRE 45° BARBED WIRE ARM  
Barbed wire arm related items shall conform to Item 550, "Chain Link Fence."



FABRIC & TENSION WIRE DETAIL, TOP & BOTTOM

GENERAL NOTES

- Items hereon shall conform to Item 550, "Chain Link Fence."
- Typical installation plan may vary as shown elsewhere as directed by the Engineer. Location of gates shown elsewhere.
- Gate-frame members shall be bolted, at frame corners, with four 1/2" bolts per joint.
- All cable connections are to be made with two 3/8" cables.
- All pull posts and end posts and their foundations shall be as approved by the Engineer. Location of gates shown elsewhere.
- All pull post shall be furnished with two stretcher bars.
- One end of each turnbuckle may be attached directly to a clevis.
- Concrete footings are to be crowned at the top to shed water.

Texas Department of Transportation

CHAIN LINK BARRIER FENCE

CLF-1


|                  |             |
|------------------|-------------|
| FILED: c1710.dgn | SHW-TxDOT   |
| © TxDOT 1996     | DATE: 08/07 |
| REVISIONS:       | DATE:       |



D

C

B



(LA500DC) 12VDC RESIDENTIAL LIGHT COMMERCIAL  
LINEAR ACTUATOR

**LiftMaster**  
LIFTMASTER (CHAMBERLAIN GROUP, INC.)  
ENGINEERED SERVICES

300 WINDSOR DR.  
DAYTON, OH 45424  
PHONE: (937) 419-4519  
FAX: (937) 419-7099

|                                |            |
|--------------------------------|------------|
| DRW. BY: B. MOFFETT            | REVISION:  |
| DATE: 07/12/2019               | SCALE: NTS |
| TITLE: LA500DC LINEAR ACTUATOR |            |
| CAD FILE: -                    |            |

SHEET NO:  
**1/1**

# POWER DEVICES

|            |   |
|------------|---|
| <b>TV</b>  | TELEVISION/LED MONITOR. RF SIGNAL AND POWER OUTLET (JUNCTION BOX AND CONDUIT BY ELECTRICAL CONTRACTOR, DEVICES BY OTHERS). REFER TO DETAIL ON E500 SERIES DRAWINGS. |
| <b>TW1</b> | TEACHER'S WORK STATION. REFER TO DETAILS ON E500 SERIES DRAWINGS.   |
| <b>WSX</b> | WORK STATION OUTLET DETAIL. REFER TO DETAILS ON E500 SERIES DRAWINGS.   |
| <b>PR</b>  | CEILING MOUNTED VIDEO PROJECTOR STATION. REFER TO DETAIL ON DRAWING E500 SERIES DRAWINGS.   |

# TELECOM OUTLETS

|  |                               |
|--|-------------------------------|
|  | OUTLET                        |
|  | OUTLET, CEILING MOUNTED       |
|  | FURNITURE SYSTEMS OUTLET      |
|  | OUTLET, MOUNTED IN FLOOR BOX  |
|  | OUTLET, MOUNTED IN POKE THRU  |
|  | OUTLET, MOUNTED IN POWER POLE |

# TELECOM OUTLET TYPES

|  |  |
|--|--|
|  | # INDICATES QUANTITY OF DATA JACKS, PULLSTRING ALWAYS PROVIDED. WHERE NO QUANTITY IS NOTED, 2 DATA JACKS AND PULLSTRING. |
|  | MOUNTED 3" ABOVE COUNTER BACKSPLASH  |
|  | BLANK FACEPLATE, ROUGH-IN ONLY   |
|  | DIRECT CONNECTION TO PANEL   |
|  | PATIENT MONITORING   |
|  | PAY TELEPHONE  |
|  | RACEWAY MOUNTED  |
|  | WALL MOUNTED TELEPHONE HANSET OUTLET   |
|  | WIRELESS ACCESS POINT CONNECTION   |

# FIRE ALARM

|             |                          |
|-------------|--------------------------|
| <b>FAA</b>  | FIRE ALARM ANNUCIATOR    |
| <b>FACP</b> | FIRE ALARM CONTROL PANEL |
| <b>DH</b>   | DOOR HOLDER              |

# WORK DEFINITION

|  |                                      |
|--|--------------------------------------|
|  | NEW WORK                             |
|  | EXISTING                             |
|  | REMOVE EXISTING                      |
|  | REMOVE EXISTING ELECTRICAL EQUIPMENT |
|  | FUTURE                               |
|  | TEMPORARY, AS NOTED                  |
|  | KEY NOTE                             |
|  | EQUIPMENT IDENTIFICATION             |

# CIRCUITS

|  |  |
|--|--|
|  | RACEWAY CONCEALED IN CEILING OR WALL. EXPOSED RACEWAY IS ALLOWED ONLY WHERE NOTED. |
|  | RACEWAY BELOW SLAB OR UNDERGROUND  |
|  | RACEWAY UP   |
|  | RACEWAY DOWN   |
|  | RACEWAY CONTINUATION   |
|  | RACEWAY STUB-OUT WITH BUSHING  |
|  | JUNCTION BOX, CEILING OR ABOVE CEILING MOUNTED                                     |
|  | JUNCTION BOX, WALL MOUNTED   |
|  | JUNCTION BOX, IN-GROUND  |
|  | PULL BOX   |

|  |  |
|--|--|
|  | EXIT SIGN, FILLED SIDES INDICATE ILLUMINATED ANNOTATION, ARROWS INDICATE DIRECTIONAL GRAPHICS              |
|  | WALL MOUNTED EXIT SIGN, FILLED SIDES INDICATE ILLUMINATED ANNOTATION, ARROWS INDICATE DIRECTIONAL GRAPHICS |
|  | EXIT SIGN WITH EMERGENCY BATTERY PACK  |
|  | WALL MOUNTED EXIT SIGN WITH EMERGENCY BATTERY PACK   |
|  | EMERGENCY BATTERY PACK, NUMBER OF LAMPS NOT INDICATED  |
|  | WALL MOUNTED EMERGENCY BATTERY PACK, NUMBER OF LAMPS NOT INDICATED   |
|  | EMERGENCY WITH REMOTE BATTERY PACK, NUMBER OF LAMPS NOT INDICATED  |
|  | WALL MOUNTED EMERGENCY WITH REMOTE BATTERY PACK, NUMBER OF LAMPS NOT INDICATED                             |
|  | RECESSED LINEAR WALL WASH LUMINAIRE, LENGTH TO SCALE   |
|  | LINEAR PENDANT MOUNTED WALL WASH LUMINAIRE, LENGTH TO SCALE  |
|  | RECESSED WALL WASH LUMINAIRE   |
|  | SURFACE MOUNTED WALL WASH LUMINAIRE  |
|  | PENDANT MOUNTED WALL WASH LUMINAIRE  |
|  | RECESSED ACCENT LUMINAIRE  |
|  | SURFACE MOUNTED ACCENT LUMINAIRE   |
|  | PENDANT MOUNTED ACCENT LUMINAIRE   |
|  | MONOPOINT LUMINAIRE  |
|  | TRACK LIGHTING   |
|  | CONTINUOUS SOURCE LUMINAIRE, PATH AS INDICATED   |
|  | MULTI-LAMP ACCENT LUMINAIRE, NUMBER OF LAMPS NOT INDICATED   |
|  | WALL MOUNTED MULTI-LAMP ACCENT LUMINAIRE, NUMBER OF LAMPS NOT INDICATED                                    |
|  | OVERCOUNTER TASK LUMINAIRE   |
|  | UNDERCABINET TASK LUMINAIRE  |
|  | FIBER OPTIC REMOTE SOURCE  |
|  | STEP LUMINAIRE   |
|  | ILLUMINATED SIGN   |
|  | WALL MOUNTED ILLUMINATED SIGN  |
|  | NIGHT LIGHT  |
|  | WALL MOUNTED STROBE LIGHT  |

# LIGHTING CONTROLS

|  |   |
|--|---|
|  | SINGLE POLE SWITCH  |
|  | INDICATES WIRELESS CONTROL                                      |
|  | LOWER-CASE LETTER(S) NEAR SWITCH DENOTE SWITCH LEG(S)           |
|  | DOUBLE POLE SWITCH  |
|  | THREE-WAY SWITCH  |
|  | FOUR-WAY SWITCH   |
|  | DIMMER SWITCH   |
|  | KEY OPERATED SWITCH   |
|  | MOMENTARY CONTACT LOW VOLTAGE SWITCH                            |
|  | OCCUPANCY SENSOR SWITCH   |
|  | OCCUPANCY SENSOR/DIMMER SWITCH                                  |
|  | SWITCH WITH PILOT LIGHT   |
|  | PHOTOCELL SWITCH  |
|  | TIMER SWITCH  |
|  | LOW VOLTAGE CONTROL STATION, # INDICATES STATION IDENTIFICATION |
|  | DIMMING SYSTEM CONTROL PANEL                                    |
|  | EMERGENCY LIGHTING CONTROL UNIT                                 |
|  | LIGHTING CONTROL PANEL  |
|  | OCCUPANCY SENSOR SWITCH, CEILING MOUNTED                        |
|  | PHOTO SENSOR CONTROL  |
|  | PHOTO SENSOR CONTROL, CEILING MOUNTED                           |
|  | RELAY   |
|  | LOW VOLTAGE TRANSFORMER   |

|  |   |
|--|---|
|  | RECEPTACLE, NEMA #  |
|  | RECEPTACLE, NEMA #, CEILING MOUNTED                         |
|  | COMBINATION RECEPTACLE, NEMA # AND 120V                     |
|  | FURNITURE SYSTEMS RECEPTACLE, 120V                          |
|  | INDICATES CONTROLLED  |
|  | INDICATES 15A   |
|  | INDICATES TWIST LOCK  |
|  | INDICATES MOUNTED 3" (75 MM) ABOVE COUNTER BACKSPLASH       |
|  | MULTI-SERVICE FLOOR BOX (RECEPTACLES/OUTLETS AS INDICATED)  |
|  | MULTI-SERVICE POKE THRU (RECEPTACLES/OUTLETS AS INDICATED)  |
|  | MULTI-SERVICE POWER POLE (RECEPTACLES/OUTLETS AS INDICATED) |
|  | MULTI-SERVICE ASSEMBLY (RECEPTACLES/OUTLETS AS INDICATED)   |
|  | CLOCK RECEPTACLE, 120V                                      |
|  | CORD DROP, 120V   |
|  | CEILING CORD DROP, 120V                                     |

# RECEPTACLE TYPES

|  |    |   |
|--|----|---|
|  | A  | ARC FAULT CIRCUIT INTERRUPTER                                 |
|  |    | ARC FAULT CIRCUIT INTERRUPTER AND TAMPER RESISTANT            |
|  | D  | DEDICATED CIRCUIT   |
|  | G  | GROUND FAULT CIRCUIT INTERRUPTER                              |
|  |    | GROUND FAULT CIRCUIT INTERRUPTER AND TAMPER RESISTANT         |
|  | IG | ISOLATED GROUND   |
|  | S  | SURGE PROTECTOR   |
|  | T  | TAMPER RESISTANT  |
|  | U  | INTEGRAL USB PORT(S)  |
|  | WP | GROUND FAULT CIRCUIT INTERRUPTER WITH WEATHER RESISTANT COVER |

# CONTROLS

|  |  |
|--|--|
|  | NON-FUSED SAFETY SWITCH  |
|  | FUSED SAFETY SWITCH, FUSE RATING INDICATED                               |
|  | COMBINATION MOTOR STARTER AND FUSED SAFETY SWITCH, FUSE RATING INDICATED |
|  | MOTOR STARTER  |
|  | MANUAL MOTOR STARTER   |
|  | AUTOMATIC DOOR PUSHPLATE   |
|  | DEAD FRONT GFCI  |
|  | EMERGENCY SHUTDOWN   |
|  | ENCLOSED CIRCUIT BREAKER   |
|  | ENCLOSED CONTACTOR   |
|  | PUSH BUTTON CONTROL STATION  |
|  | TOGGLE SWITCH, MOTOR RATED   |
|  | TOUCHLESS AUTOMATIC DOOR OPENER  |
|  | DIRECT DIGITAL CONTROL PANEL   |
|  | RELAY  |
|  | THERMOSTAT   |
|  | TIME CLOCK   |
|  | VARIABLE FREQUENCY DRIVE   |

# ELECTRICAL EQUIPMENT

|  |  |
|--|--|
|  | 208V OR 240V POWER PANELBOARD                          |
|  | 480V OR 600V POWER PANELBOARD                          |
|  | EQUIPMENT CABINET OR PANEL                             |
|  | EQUIPMENT CONNECTION. FILL INDICATES EMERGENCY CIRCUIT |
|  | GROUND BAR   |
|  | MOTOR CONNECTION, 1Ø                                   |
|  | MOTOR CONNECTION, 3Ø                                   |
|  | BUS DUCT   |
|  | AUTOMATIC TRANSFER SWITCH                              |
|  | BUS DUCT PLUG  |
|  | SURGE PROTECTIVE DEVICE                                |
|  | TRANSFORMER, NOT TO SCALE                              |
|  | TRANSFORMER, DRAWN TO SCALE                            |

|              |                                       |          |   |
|--------------|---------------------------------------|----------|---|
| BC           | BONDING CONDUCTOR                     | MECH     | MECHANICAL                                    |
| BCU          | BARE COPPER                           | MET      | METAL   |
| BFC          | BELOW FINISHED CEILING                | MFR      | MATERIAL                                      |
| BFG          | BELOW FINISHED GRADE                  | MH       | MANHOLE                                       |
| BKR          | BREAKER                               | MIN      | MINIMUM                                       |
| BLDG         | BUILDING                              | MISC     | MISCELLANEOUS                                 |
| BOF          | BOTTOM OF FIXTURE                     | MLO      | MATERIAL LIST                                 |
| BTM          | BOTTOM                                | MM       | MILLIMETER                                    |
| C            | CONDUIT                               | MSB      | MATERIAL SCHEDULE                             |
| CW           | COMPLETE WITH                         | MTD      | MATERIAL TAKE OFF                             |
| CAP          | CAPACITY                              | MTG      | MATERIAL TAKE OFF                             |
| CATV         | CABLE ANTENNA TELEVISION              | MTS      | MATERIAL TAKE OFF                             |
| CB           | CIRCUIT BREAKER                       | MV       | MATERIAL TAKE OFF                             |
| CCTV         | CLOSED CIRCUIT TELEVISION             | MVCB     | MATERIAL TAKE OFF                             |
| CEC          | CANADIAN ELECTRIC CODE                | MW       | MATERIAL TAKE OFF                             |
| CFOI         | CONTRACTOR FURNISHED, OWNER INSTALLED | N        | NOTED   |
| CIRC         | CIRCULATING                           | NAC      | NOTED   |
| CKT          | CIRCUIT                               | NC       | NOTED   |
| CL           | CENTERLINE                            | NEC      | NATIONAL ELECTRICAL CODE                      |
| CLG          | CEILING                               | NEMA     | NATIONAL ELECTRICAL MANUFACTURERS ASSOCIATION |
| CM           | CEILING MOUNTED                       | NIC      | NOTED   |
| CMU          | CONCRETE MASONRY UNIT                 | NL       | NOTED   |
| CO           | CONDUIT ONLY                          | NO       | NOTED   |
| COMM         | COMMUNICATIONS                        | NTS      | NOT TO SCALE                                  |
| CONC         | CONCRETE                              | OC       | OVERCOUNTER                                   |
| CONN         | CONNECTION                            | OD       | OVERCOUNTER                                   |
| CONST        | CONSTRUCTION                          | OFCI     | OFFICE  |
| CONT         | CONTINUOUS                            | OFE      | OFFICE  |
| CONTR        | CONTRACTOR                            | OH       | OVERHEAD                                      |
| CPT          | CONTROL POWER TRANSFORMER             | OL       | OVERHEAD                                      |
| CPU          | CENTRAL PROCESSING UNIT               | OS       | OVERHEAD                                      |
| CR           | CRITICAL BRANCH                       | OSP      | OVERHEAD                                      |
| CT           | CURRENT TRANSFORMERS                  | P        | POWER   |
| CTR          | CENTER                                | PA       | POWER   |
| CU           | COPPER                                | PB       | POWER   |
| CUH          | CABINET UNIT HEATER                   | PD       | POWER   |
| D            | DEDICATED                             | PF       | POWER   |
| DC           | DIRECT CURRENT                        | PH       | POWER   |
| DET          | DETAIL                                | PNL      | POWER   |
| DIAM         | DIAMETER                              | POE      | POWER   |
| DIM          | DIMENSION                             | POS      | POWER   |
| DISC         | DISCONNECT                            | PT       | POWER   |
| DIV          | DIVISION                              | PTS      | POWER   |
| DL           | DAMP LOCATION                         | PTZ      | POWER   |
| DN           | DOWN                                  | PV       | POWER   |
| DP           | DISTRIBUTION PANEL                    | PVC      | POWER   |
| DPDT         | DOUBLE POLE, DOUBLE THROW             | PWR      | POWER   |
| DPR          | DAMPER                                | R        | RAISED  |
| DPST         | DOUBLE POLE, SINGLE THROW             | RA       | RAISED  |
| DWG          | DRAWING                               | REC      | RECORD  |
| DWH          | DOMESTIC WATER HEATER                 | RECP     | RECORD  |
| EA           | EACH                                  | REQD     | REQUIRED                                      |
| EC           | ELECTRICAL CONTRACTOR                 | REX      | RECORD  |
| EF           | EXHAUST FAN                           | RM       | ROOM  |
| ELEC         | ELECTRICAL                            | RNC      | ROOM  |
| ELEV         | ELEVATOR                              | RO       | ROOM  |
| EM           | EMERGENCY                             | RSC, RGS | ROOM  |
| EM GEN       | EMERGENCY GENERATOR                   | SCCR     | ROOM  |
| EMT          | ELECTRICAL METALLIC TUBING            | SEC      | ROOM  |
| ENCL         | ENCLOSURE                             | SECT     | ROOM  |
| EP           | ELECTRIC-PNEUMATIC                    | SIM      | ROOM  |
| EPO          | EMERGENCY POWER OFF                   | SM       | ROOM  |
| EQ           | EQUIPMENT BRANCH                      | SMR      | ROOM  |
| EQUIP        | EQUIPMENT                             | SPD      | ROOM  |
| ERL          | EXISTING TO BE RELOCATED              | SPDT     | ROOM  |
| ETD          | EMERGENCY TRANSFER DEVICE             | SPTS     | ROOM  |
| EWC          | ELECTRIC WATER COOLER                 | SS       | ROOM  |
| EXH          | EXHAUST                               | ST       | ROOM  |
| EXIST, E, EX | EXISTING                              | STD      | ROOM  |
| EXP          | EXPLOSION PROOF                       | SW       | ROOM  |
| EXTER        | EXTERIOR                              | SWBD     | ROOM  |
| F&I          | FURNISHED AND INSTALLED               | SWGR     | ROOM  |
| FA           | FIRE ALARM                            | SYS      | ROOM  |
| FAA          | FIRE ALARM ANNUCIATOR                 | TBB      | ROOM  |
| FACP         | FIRE ALARM CONTROL PANEL              | TC       | ROOM  |
| FB           | FLOOR BOX                             | TE       | ROOM  |
| FCU          | FAN COIL UNIT                         | TELE     | ROOM  |
| FLOOR        | FLOOR                                 | TELECOM  | ROOM  |
| FLUOR        | FLUORESCENT                           | TEMP     | ROOM  |
| FO           | FIBER (FIBRE) OPTIC                   | TERM     | ROOM  |
| FP           | FIRE PROTECTION                       | TGB      | ROOM  |
| FS           | FUSIBLE SWITCH                        | TMGB     | ROOM  |
| FSCS         | FIRE FIGHTER SMOKE CONTROL STATION    | TOF      | ROOM  |
| FU           | FUSE                                  | TP       | ROOM  |
| FVNR         | FULL VOLTAGE NON REVERSING            | TR       | ROOM  |
| FVR          | FULL VOLTAGE REVERSING                | TSP      | ROOM  |
| G, GND       | GROUND                                | TSTAT    | ROOM  |
| GY           | GREEN YELLOW                          |          |   |
| GA           | GAUGE                                 |          |   |

D

C

B

D

1. WHENEVER USED IN THESE SPECIFICATIONS OR DRAWINGS, THE FOLLOWING TERMS SHALL HAVE THE INDICATED MEANINGS:

- A. FURNISH: TO SUPPLY AND DELIVER TO THE PROJECT SITE, READY FOR UNLOADING, UNPACKING, ASSEMBLING, INSTALLING, AND SIMILAR OPERATIONS.
- B. INSTALL: TO PERFORM ALL OPERATIONS AT THE PROJECT SITE, INCLUDING, BUT NOT LIMITED TO, AND AS REQUIRED: UNLOADING, UNPACKING, ASSEMBLING, ERECTING, PLACING, ANCHORING, APPLYING, WORKING TO DIMENSION, FINISHING, CURING, PROTECTING, CLEANING, TESTING, COMMISSIONING, STARTING UP AND SIMILAR OPERATIONS, COMPLETE, AND READY FOR THE INTENDED USE.
- C. PROVIDE: TO FURNISH AND INSTALL COMPLETE, AND READY FOR THE INTENDED USE.
- D. FURNISHED BY OWNER (OR OWNER-FURNISHED) OR FURNISHED BY OTHERS: AN ITEM FURNISHED BY THE OWNER OR UNDER OTHER DIVISIONS OR CONTRACTS, AND INSTALLED UNDER THE REQUIREMENTS OF THIS DIVISION, COMPLETE, AND READY FOR THE INTENDED USE, INCLUDING ALL ITEMS AND SERVICES INCIDENTAL TO THE WORK NECESSARY FOR PROPER INSTALLATION AND OPERATION. INCLUDE THE INSTALLATION UNDER THE WARRANTY REQUIRED BY THIS DIVISION.
- E. ENGINEER: WHERE REFERENCED IN THIS DIVISION, "ENGINEER" IS THE ENGINEER OF RECORD AND THE DESIGN PROFESSIONAL FOR THE WORK UNDER THIS DIVISION, AND IS A CONSULTANT TO, AND AN AUTHORIZED REPRESENTATIVE OF, THE ARCHITECT, AS DEFINED IN THE GENERAL AND/OR SUPPLEMENTARY CONDITIONS. WHEN USED IN THIS DIVISION, IT MEANS INCREASED INVOLVEMENT BY, AND OBLIGATIONS TO, THE ENGINEER, IN ADDITION TO INVOLVEMENT BY, AND OBLIGATIONS TO, THE "ARCHITECT".

2. AHJ: THE LOCAL CODE AND/OR INSPECTION AGENCY, AUTHORITY HAVING JURISDICTION OVER THE WORK.

3. NRTL: NATIONALLY RECOGNIZED TESTING LABORATORY, AS DEFINED AND LISTED BY OSHA IN 29 CFR 1910.7 (E.G., UL, ETL, CSA), AND ACCEPTABLE TO THE AHJ OVER THIS PROJECT.

4. THE TERMS "EQUIVALENT", OR "EQUAL" ARE USED SYNONYMOUSLY AND SHALL MEAN "ACCEPTED BY OR ACCEPTABLE TO THE ENGINEER AS EQUIVALENT TO THE ITEM OR MANUFACTURER SPECIFIED". "EQUIVALENT" OR "EQUAL" PRODUCTS SHALL BE LABELED, LISTED, CERTIFIED, OR ALL THREE, BY AN NRTL, AND ACCEPTABLE TO THE AHJ OVER THIS PROJECT.

### 1-3 PRE-BID SITE VISIT

1. PERSONALLY INSPECT THE SITE OF THE PROPOSED WORK AND BECOME FULLY INFORMED OF CONDITIONS UNDER WHICH THE WORK IS TO BE DONE. FAILURE TO DO SO WILL NOT BE CONSIDERED SUFFICIENT JUSTIFICATION TO REQUEST OR OBTAIN EXTRA COMPENSATION OVER AND ABOVE THE CONTRACT PRICE.

### 1-4 MATERIAL AND WORKMANSHIP

1. PROVIDE ALL MATERIAL AND EQUIPMENT NEW AND IN FIRST CLASS CONDITION. PROVIDE MARKINGS OR A NAMEPLATE FOR ALL MATERIAL AND EQUIPMENT IDENTIFYING THE MANUFACTURER AND PROVIDING SUFFICIENT REFERENCE TO ESTABLISH QUALITY, SIZE AND CAPACITY. ALL WORKMANSHIP SHALL BE OF THE FINEST QUALITY, AS DEFINED BY THE MANUFACTURER'S SPECIFICATIONS AND EQUIPMENT (SEE TRADE AND RESIDENTIAL TRADE SPECIFICATIONS). PROVIDE THE EQUIPMENT WILL NOT BE ACCEPTABLE):  
A. COMMERCIAL HEAVY DUTY GRADE

2. PROVIDE ALL HOISTS, SCAFFOLDS, STAGING, RUNWAYS, TOOLS, MACHINERY, AND EQUIPMENT REQUIRED FOR THE INSTALLATION AND PERFORMANCE OF THE ELECTRICAL WORK. STORE AND MAINTAIN MATERIAL AND EQUIPMENT IN CLEAN CONDITION, AND PROTECTED FROM WEATHER, MOISTURE, AND PHYSICAL DAMAGE.

3. FURNISH ONLY MATERIAL AND EQUIPMENT THAT ARE LISTED, LABELED, CERTIFIED, OR ALL THREE, BY A NATIONALLY RECOGNIZED TESTING LABORATORY, WHENEVER ANY LISTING OR LABELING EXISTS FOR THE TYPES OF MATERIAL AND EQUIPMENT SPECIFIED. AT A MINIMUM, GENERAL WORK PRACTICES FOR ELECTRICAL CONSTRUCTION SHALL BE IN ACCORDANCE WITH NECA 1 (LATEST EDITION), \* STANDARD PRACTICES FOR GOOD WORKMANSHIP IN ELECTRICAL CONSTRUCTION.

### 1-5 MANUFACTURERS

1. IN OTHER ARTICLES WHERE LISTS OF MANUFACTURERS ARE INTRODUCED, SUBJECT TO COMPLIANCE WITH REQUIREMENTS, PROVIDE PRODUCTS BY ONE OF THE MANUFACTURERS SPECIFIED.

2. WHERE MANUFACTURERS ARE NOT LISTED, PROVIDE PRODUCTS SUBJECT TO COMPLIANCE WITH REQUIREMENTS FROM MANUFACTURERS THAT HAVE BEEN ACTIVELY INVOLVED IN MANUFACTURING THE SPECIFIED PRODUCT FOR NO LESS THAN 5 YEARS.

### 1-6 COORDINATION

1. COORDINATE ALL WORK WITH OTHER DIVISIONS AND TRADES SO THAT VARIOUS COMPONENTS OF THE ELECTRICAL SYSTEMS ARE INSTALLED AT THE PROPER TIME, FIT THE AVAILABLE SPACE, AND ALLOW PROPER SERVICE ACCESS TO ALL EQUIPMENT. REFER TO ALL DRAWINGS, INCLUDING, BUT NOT LIMITED TO CIVIL, ARCHITECTURAL, STRUCTURAL, MECHANICAL, PLUMBING AND TO RELEVANT EQUIPMENT SUBMITTALS AND SHOP DRAWINGS TO DETERMINE THE EXTENT OF CLEAR SPACES. MAKE ALL OFFSETS REQUIRED TO CLEAR EQUIPMENT, BEAMS AND OTHER STRUCTURAL MEMBERS, AND TO FACILITATE CONCEALING RACEWAYS IN THE MANNER ANTICIPATED IN THE DESIGN. PROVIDE MATERIALS WITH TRIM THAT WILL FIT PROPERLY THE TYPES OF CEILING, WALL, OR FLOOR FINISHES ACTUALLY INSTALLED.

### 1-7 ORDINANCES, CODES, AND CLIENT

1. COMPLY WITH NATIONAL FIRE PROTECTION ASSOCIATION (NFPA) STANDARDS, STATE AND LOCAL BUILDING CODES, AND ALL OTHER APPLICABLE CODES AND ORDINANCES FOR PERFORMANCE, WORKMANSHIP, EQUIPMENT, AND MATERIALS. ADDITIONALLY, COMPLY WITH RULES AND REGULATIONS OF PUBLIC UTILITIES AND MUNICIPAL DEPARTMENTS AFFECTED BY CONNECTION OF SERVICES.

2. WHERE CONFLICTS BETWEEN VARIOUS CODES, ORDINANCES, RULES, AND REGULATIONS EXIST, COMPLY WITH THE MOST STRINGENT. WHEREVER REQUIREMENTS OF THESE SPECIFICATIONS, DRAWINGS, OR BOTH EXCEED THOSE OF THE ABOVE ITEMS, THE REQUIREMENTS OF THESE SPECIFICATIONS, DRAWINGS, OR BOTH SHALL GOVERN. CODE COMPLIANCE TO A MINIMUM IS A MANDATORY CONTRACT REQUIREMENT IN THESE CODES.

3. PROVIDE AND MAINTAIN ALL NECESSARY SIGNAL LIGHTS AND GUARDS FOR THE SAFETY OF THE PUBLIC.

C

B

CONTRACTOR FROM RESPONSIBILITY IN DIMENSIONS, DETAILS, SIZE OF MEMBERS, QUANTITIES; OR FOR OMITTING COMPONENTS OR FITTINGS; OR FOR NOT COORDINATING ITEMS WITH ARCHITECT BUILDING CONDITIONS.

## 1-10 ELECTRONIC DRAWING FILES

1. ELECTRONIC FILES FOR AS-BUILT COMPLETION CAN BE PROVIDED TO CONTRACTORS UPON REQUEST.

## 1-11 TRAINING

1. AT A TIME MUTUALLY AGREED UPON BETWEEN THE OWNER AND CONTRACTOR, TRAIN OWNER'S DESIGNATED PERSONNEL ON THE OPERATION AND MAINTENANCE OF THE EQUIPMENT PROVIDED FOR THIS PROJECT.

2. PROVIDE TRAINING TO INCLUDE BUT NOT BE LIMITED TO AN OVERVIEW OF THE SYSTEM AND/OR EQUIPMENT AS IT RELATES TO THE FACILITY AS A WHOLE; OPERATION AND MAINTENANCE PROCEDURES AND SCHEDULES RELATED TO STARTUP AND SHUTDOWN, TROUBLESHOOTING, SERVICING, PREVENTIVE MAINTENANCE AND APPROPRIATE OPERATOR INTERVENTION; AND REVIEW OF DATA INCLUDED IN THE OPERATION AND MAINTENANCE INSTRUCTIONS.

3. SCHEDULE TRAINING WITH OWNER WITH AT LEAST 7 DAYS IN ADVANCE NOTICE.

## 1-12 WARRANTIES

1. WARRANT EACH SYSTEM AND EACH ELEMENT THEREOF AGAINST ALL DEFECTS DUE TO FAULTY WORKMANSHIP, INSTALLATION, PRODUCT DESIGN OR MATERIAL FOR A PERIOD OF 12 MONTHS FROM THE DATE OF SUBSTANTIAL COMPLETION, UNLESS SPECIFIC ITEMS ARE NOTED TO CARRY A LONGER WARRANTY. THE CONSTRUCTION DOCUMENTS OR MANUFACTURER'S STANDARD WARRANTY EXCEEDS THE WARRANTY PERIOD(S), AS STATED IN THE GENERAL CONDITIONS.

2. ALSO WARRANT THE FOLLOWING ADDITIONAL ITEMS:

A. ALL RACEWAYS ARE FREE FROM OBSTRUCTIONS, HOLES, CRUSHING, OR BREAKS OF ANY KIND.  
B. ALL RACEWAY SEALS ARE EFFECTIVE.

C. THE ENTIRE ELECTRICAL SYSTEM IS FREE FROM ALL SHORT CIRCUITS AND UNWANTED OPEN CIRCUITS AND GROUNDS.

3. THE ABOVE WARRANTIES SHALL INCLUDE LABOR AND MATERIAL. MAKE REPAIRS OR REPLACE DEFECTIVE ITEMS WITHOUT ANY ADDITIONAL COSTS TO THE OWNER.

4. PERFORM THE REMEDIAL WORK PROMPTLY, UPON WRITTEN NOTICE FROM THE ENGINEER OR OWNER.

5. AT THE TIME OF SUBSTANTIAL COMPLETION, DELIVER TO THE OWNER ALL WARRANTIES, IN FULLY EXECUTED, INCLUDING TERM LIMITS FOR WARRANTIES EXTENDING BEYOND THE WARRANTY PERIOD. EACH WARRANTY INSTRUMENT BEING ADDRESSED TO THE OWNER AND STATING THE COMMENCEMENT DATE AND TERM.

## 1-13 MISCELLANEOUS REMODELING WORK

1. PROVIDE ALL DEMOLITION OF EXISTING ELECTRICAL SYSTEMS AND NEW ELECTRICAL SYSTEMS REQUIRED BECAUSE OF BUILDING REMODELING. AS NOTED ON THE DRAWINGS, OR NECESSARY FOR PROPER OPERATION AND NEW CONSTRUCTION, REMOVE ALL ABANDONED CABLES AND WIRING ABOVE ACCESSIBLE CEILINGS AND VENTILATION SHAFTS.

2. EXERCISE EXTREME CAUTION IN THE INSTALLATION OF THIS WORK TO AVOID AN ELECTRICAL ACCIDENT. THE FACILITY IS EXISTING AND MAY REMAIN IN OPERATION DURING THIS WORK. COORDINATE ALL WORK SCHEDULES WITH THE BUILDING MANAGEMENT PRIOR TO DE-ENERGIZING ANY ELECTRICAL CIRCUITS TO AVOID CONFLICTS WITH ANY OTHER TENANT'S OPERATION. ALLOW 3 DAYS PRIOR CONFIRMED NOTIFICATION.

3. VERIFY THAT NEW AND EXISTING TO REMAIN INSTALLATIONS ARE CODE COMPLIANT, AND MAKE CORRECTIONS AS REQUIRED.

4. DEVELOP AND MAINTAIN A SET OF "RED-LINE AS-BUILT" DRAWINGS. THESE DRAWINGS SHALL BE MAINTAINED AT THE PROJECT CONSTRUCTION SITE AND AVAILABLE TO THE ENGINEER UPON REQUEST. THEY SHALL BE CURRENT AND SHALL REFLECT ALL ACTUAL ASPECTS OF THE ELECTRICAL INSTALLATION WHICH DEVIATED FROM THE PRESENT ELECTRICAL DESIGN DRAWINGS. THESE DRAWINGS SHALL BE SUBMITTED TO THE ENGINEER WITHIN 10 DAYS OF SUBSTANTIAL COMPLETION OF THE WORK AND MUST INCLUDE ALL PUNCH LIST ITEMS.

5. VERIFY THE LOADING OF EACH CIRCUIT AFFECTED BY THE REMODELING. DO NOT LOAD CIRCUITS TO MORE THAN 80% OF THEIR RATING.

6. PROVIDE UPDATED, TYPED DIRECTORY FOR EACH PANELBOARD BEING USED OR MODIFIED UNDER THIS CONTRACT. DESIGNATE NEW CIRCUITS AND AREA BEING SERVED.

7. FLEXIBLE STEEL CONDUIT SHALL BE USED TO WIRE ALL LIGHT FIXTURES AND VIBRATING EQUIPMENT IN LENGTHS FROM 18 INCHES TO 72 INCHES ONLY.

8. CONDUIT AND CABLE ABOVE CEILING SHALL BE SUPPORTED BY A UNISTRUT AND ALL THREE TRAPEZE. EACH PIECE OF CONDUIT SHALL BE SECURED TO THE TRAPEZE WITH A CONDUIT STRAP. THE TRAPEZE SUPPORTS SHALL BE INSTALLED PER CODE PLUS A MINIMUM OF 12" ABOVE THE CEILING.

9. NO CHANGE ORDER SHALL BE ISSUED DURING CONSTRUCTION FOR CHANGES DUE TO INCOMPATIBILITY. NO CHANGES SHALL BE MADE TO THE CIRCUITING SHOWN WITHOUT PRIOR WRITTEN APPROVAL OF THE ENGINEER OF RECORD. CIRCUIT NUMBERS SHALL BE INDICATED ON EACH JUNCTION BOX.

10. AT THE TIME OF FINAL PUNCH LIST, AN ELECTRICIAN MAY BE REQUIRED TO ASSIST IN THE REMOVAL OF PANEL COVERS, JUNCTION BOX COVERS, RECEPTACLES, SWITCHES, AND OTHER ELECTRICAL DEVICES.

## PART 2 ELECTRICAL WORK 2-1 BUILDING OPERATION



4. USE INSULATED, GROUNDING, OR COMBINATION BUSHINGS WHEREVER CONNECTION IS SUBJECT TO VIBRATION OR MOISTURE, WHEN REQUIRED BY NFPA 70, OR BOTH.

5. INSTALL PLASTIC BUSHINGS ON THE CONNECTIONS OF ALL REUSED CONDUIT.

### 4-1-4 CONDUCTORS AND CABLES

1. ALL FEEDER AND BRANCH CIRCUIT CONDUCTORS NO. 12 AWG AND LARGER: STRANDED, TYPE THHN-2 OR XHHW-2 INSULATION.
2. ALL BRANCH CIRCUIT WIRING: SHALL NOT BE NOT SMALLER THAN NO. 12 AWG. IF NO CONDUCTOR SIZE IS INDICATED ON THE DRAWINGS FOR A BRANCH CIRCUIT, PROVIDE CONDUCTORS AND CONDUIT SIZED PER NFPA 70 AND BASED ON THE INDICATED BRANCH CIRCUIT OVERCURRENT PROTECTIVE DEVICE (OCPD) RATING AND NUMBER OF POLES. WHERE NO CIRCUIT SIZE (I.E., CONDUCTORS AND OCPD) IS INDICATED ON THE DRAWINGS FOR A BRANCH CIRCUIT, PROVIDE THREE NO. 12 AWG CONDUCTORS, IN 3/4-INCH RACEWAY, AND A 20A CIRCUIT BREAKER.
3. CONDUCTORS FIELD-INSTALLED WITHIN LIGHT FIXTURE CHANNELS: TYPE THHN.
4. CONTROL WIRING: STRANDED COPPER CONDUCTORS, 600V INSULATION, OF THE PROPER TYPE, SIZE AND NUMBER AS REQUIRED TO ACCOMPLISH SPECIFIED FUNCTION. MINIMUM SIZE: NO. 14 AWG, UNLESS NOTED OTHERWISE.
5. CONDUCTOR MATERIAL:
  - A. ANNEALED (SOFT) COPPER COMPLYING WITH ICEA S-95-658/NEMA WC70; SOLID CONDUCTOR FOR NO. 12 AWG AND SMALLER; CONCENTRIC, COMPRESSED-STRANDED FOR NO. 10 AWG AND LARGER.
  - B. CONDUCTOR INSULATION TYPES: 90-DEGREE C-RATED, TYPE THHN/THWN-2 OR XHHW-2 COMPLYING WITH ICEA S-95-658/NEMA WC70, UNLESS NOTED OTHERWISE IN THE DRAWINGS.
  - C. SIZES OF CONDUCTORS AND CABLES INDICATED OR SPECIFIED ARE IN AMERICAN WIRE GAGE (AWG - BROWN AND SHARPE).
  - D. UNLESS INDICATED OTHERWISE, SPECIAL PURPOSE CONDUCTORS AND CABLES, SUCH AS LOW VOLTAGE 4. CONTROL AND SHIELDED INSTRUMENT WIRING, SHALL BE AS RECOMMENDED BY THE SYSTEM EQUIPMENT MANUFACTURER.

### 4-1-5 INSTALLATION OF CONDUCTORS AND CABLES

1. INSTALL ALL WIRING IN APPROVED RACEWAY AND ENCLOSURES, EXCEPT WHERE SPECIFIED OR INDICATED OTHERWISE.
2. SUPPORT ALL CONDUCTORS AND CABLES IN VERTICAL INSTALLATIONS, AS REQUIRED BY NFPA 70, BY INSTALLING CABLE SUPPORTS OR PLUG-TYPE CONDUIT RISER SUPPORTS OR WIRE-MESH SAFETY GRIPS.
3. INSTALL ALL CONDUCTORS AND CABLE IN CONTINUOUS RACEWAY WITHOUT TAPS OR SPLICES. SPLICE OR TAP ONLY IN APPROVED BOXES AND ENCLOSURES WITH APPROVED SOLDERLESS CONNECTORS; OR CRIMP CONNECTORS AND TERMINAL BLOCKS FOR CONTROL WIRING, AND; KEEP TO THE MINIMUM REQUIRED. INSULATE ALL SPLICES, TAPS AND JOINTS AS REQUIRED BY CODES.
4. ALL MATERIALS USED TO TERMINATE, SPLICE OR TAP CONDUCTORS: DESIGNED PROPERLY SIZED AND UL-LISTED FOR THE SPECIFIC APPLICATION AND CONDUCTORS INVOLVED. INSTALL IN STRICT ACCORDANCE WITH THE MANUFACTURER'S RECOMMENDATIONS, USING THE MANUFACTURER'S RECOMMENDED TOOLS.
5. WHERE WIRING IS INDICATED AS INSTALLED, BUT THE CONNECTION IS INDICATED "FUTURE" OR "BY OTHERS" DIVISION, TRADE, OR CONTRACT; LEAVE A MINIMUM 3-FOOT "PIGTAIL" AT THE BOX, TAPE THE ENDS OF THE CONDUCTORS AND COVER THE BOX. IN GENERAL, BRANCH CIRCUIT "HOME RUN" ROUTING IS INDICATED ON THE DRAWINGS. COMPLETE WITH CIRCUIT NUMBERS AND PANELBOARD DESIGNATION. CONTINUE ALL SUCH "HOME RUN" WIRING TO THE DESIGNATED PANELBOARD, AS THOUGH "CIRCUIT RUNS" WERE INDICATED IN THEIR ENTIRETY.
6. WHEN MULTIPLE HOME RUNS ARE COMBINED INTO A SINGLE RACEWAY SUCH THAT THE NUMBER OF CONDUCTORS EXCEEDS FOUR (CONDUCTOR COUNT IS MADE UP OF ANY COMBINATION OF PHASE AND NEUTRAL CONDUCTORS), THE FOLLOWING RESTRICTIONS APPLY, WHICH ARE IN ADDITION TO THOSE IN NFPA 70:
  7. EMERGENCY POWER CIRCUITS - INCLUDES ALL CIRCUITS COVERED UNDER ARTICLES 700, 701 AND 702:
    - A. MAXIMUM OF 16 CONDUCTORS IN A SINGLE RACEWAY. FOR UP TO EIGHT CONDUCTORS IN A RACEWAY, A MINIMUM RACEWAY SIZE: 3/4-INCH. FOR GREATER THAN EIGHT CONDUCTORS, MINIMUM RACEWAY SIZE: 1-INCH. DO NOT INSTALL ANY OTHER TYPE OF CIRCUIT IN THIS RACEWAY.
    - B. THE MINIMUM WIRE SIZE FOR ALL CONDUCTORS IN THIS RACEWAY: NO. 10 AWG.
    - C. ONLY 15A AND 20A BRANCH CIRCUIT HOMERUNS MAY BE COMBINED INTO ONE RACEWAY.
8. GFCI CIRCUITS:
  - A. DO NOT USE MULTI-CONDUCTOR CIRCUITS, WITH A SHARED NEUTRAL, FOR ANY GFCI CIRCUIT BREAKER OR RECEPTACLE CIRCUIT.
  - B. FOR BRANCH CIRCUITS FED FROM GFCI CIRCUIT BREAKERS, LIMIT THE ONE-WAY CONDUCTOR LENGTH TO 100 FEET BETWEEN THE PANELBOARD AND THE MOST REMOTE RECEPTACLE OR LOAD ON THE GFCI CIRCUIT.
9. WIRING SHALL HAVE INSULATION OF THE PROPER COLOR TO MATCH COLOR CODE SYSTEM IN THE TABLE BELOW. ALL CONDUCTORS AND CABLES NOT PROPERLY COLOR CODED SHALL BE REMOVED AND REPLACED AT THE CONTRACTORS EXPENSE. CONDUCTORS SHALL HAVE CONTINUOUS COLOR CODED OUTER JACKET. IN LARGER SIZES, WHERE PROPERLY COLORED INSULATION IS NOT AVAILABLE, USE VINYL PLASTIC ELECTRICAL TAPE OF THE APPROPRIATE COLOR AROUND EACH CONDUCTOR AT ALL TERMINATION POINTS, JUNCTION AND PULL BOXES.
10. WIRING SHALL HAVE INSULATION OF THE PROPER COLOR TO MATCH COLOR CODE SYSTEM IN THE TABLE BELOW. ALL CONDUCTORS AND CABLES NOT PROPERLY COLOR CODED SHALL BE REMOVED AND REPLACED AT THE CONTRACTORS EXPENSE. CONDUCTORS SHALL HAVE CONTINUOUS COLOR CODED OUTER JACKET. IN LARGER SIZES, WHERE PROPERLY COLORED INSULATION IS NOT AVAILABLE, USE VINYL PLASTIC ELECTRICAL TAPE OF THE APPROPRIATE COLOR AROUND EACH CONDUCTOR AT ALL TERMINATION POINTS, JUNCTION AND PULL BOXES.
11. REFERENCE DETAIL FOR SYSTEM VOLTAGE:

| System Voltage | Conductor Type | Color |
|----------------|----------------|-------|
|----------------|----------------|-------|

D

C

B


D

C

B

WATER TRENCH


TO BE BUILT



D

C

B



**EXISTING TEMPORARY BUILDING**

**EXISTING TEMPORARY BUILDING**


**EXISTING NEW TECH HIGH SCHOOL BUILDING**

**EXISTING CAFETERIA**

**EXISTING NEW TECH MIDDLE SCHOOL BUILDING**


**EXISTING BUILDING**

**EXISTING MEDICAL BUILDING**




FRONT VIEW

CARD READER AND INTERCOM BOX DETAIL



FRONT VIEW

LOWER CARD READER AND INTERCOM BOX DETAIL




SECURITY PEDESTAL ELEVATION

GENERAL NOTES:

1. UNLESS OTHERWISE NOTED, ALL FASTENERS, SCREWS, BOLTS/ANCHORS AND OTHER MOUNTING ACCESSORIES SHALL BE MADE OF 316 STAINLESS STEEL.

**1** T501 NTS **TYPICAL CARD READER PEDESTAL DETAIL**




SECURITY PEDESTAL ELEVATION



GENERAL NOTES:

1. UNLESS OTHERWISE NOTED, ALL FASTENERS, SCREWS, BOLTS/ANCHORS AND OTHER MOUNTING ACCESSORIES SHALL BE MADE OF 316 STAINLESS STEEL.

**2** T501 NTS **TYPICAL CARD READER/INTERCOM PEDESTAL DETAIL**



**3** T501 NTS **CARD READER/INTERCOM BOX DETAIL**



**4** T501 NTS **CARD READER PEDESTAL DETAIL**

