

MAINTENANCE REPORT JANUARY 2025

Submitted by: Reid Reagan

Maintenance staff has been busy with snow removal, roof leaks, and keeping the buildings warm. In addition we have assisted in the setup/cleanup of basketball games, wrestling and high wind events. We have responded to 97 work orders all repair or service calls.

BHS:

Install new kitchen cabinets/cupboards in the Home Ec room. Install new TV. Remove coils from AHU supplying A and C wings, offices, library and kitchen/cafetorium areas, reinstall the new ac/heat coils.

BULLSHOE:

Clean up water, install new ceiling tiles and unit ventilator, heat restored.

BMS:

Remove and relocate white boards.

NAPI:

FICO install new temperature control sensor in the gymnasium, able to monitor gym on the Building Automated System (BAS) Install new TV, remove and relocate another TV.

Trailer Park:

Shut off water supply, remove cracked shutoff valve to home, Install new shutoff valve, back online. Reinstall metal skirting on mobile home caused by high winds.

BES:

Install new TVs.