

LAB FEDERAL ID#:		ID00013
DATE RECEIVED:	DATE REPORTED BY LAB:	
8/12/2016	8/24/2016	
COMPLIANCE SAMPLE: YES	REPLACEMENT SAMPLE: NO	
SAMPLE TYPE:		
PWS #:	PWS NAME:	
	PENDLETON SCHOOL DISTRICT	
CONTACT NAME:		CONTACT PHONE:
TABLE ROCK ANALYTICAL LAB		



Anatek Labs, Inc.

1282 Alturas Drive
Moscow, ID 83843
(208) 883-2839
FAX 882-9246
moscow@anateklabs.com

504 E. Sprague Ste. D
Spokane, WA 99202
(509) 838-3999
FAX 838-4433
spokane@anateklabs.com

www.anateklabs.com

Lead Analysis Report

Lab Sample #	Sample Location	Collection Date / Time	Analyte	Result	Method	Analysis Date	Analyst	Qualifier
160815008-001	160811A20 / SMS 5	8/11/2016 7:09 AM	Lead	ND	EPA 200.8	8/19/2016	ETL	
160815008-002	160811A21 / SMS 6	8/11/2016 7:11 AM	Lead	0.00616	EPA 200.8	8/19/2016	ETL	
160815008-003	160811A22 / SMS 7	8/11/2016 7:13 AM	Lead	0.0110	EPA 200.8	8/19/2016	ETL	
160815008-004	160811A23 / SMS 8	8/11/2016 7:18 AM	Lead	0.00112	EPA 200.8	8/19/2016	ETL	
160815008-005	160811A24 / SMS 9	8/11/2016 7:19 AM	Lead	0.00429	EPA 200.8	8/19/2016	ETL	
160815008-006	160811A25 / SMS 10	8/11/2016 7:23 AM	Lead	ND	EPA 200.8	8/19/2016	ETL	
160815008-007	160811A26 / SMS 11	8/11/2016 7:25 AM	Lead	ND	EPA 200.8	8/19/2016	ETL	
160815008-008	160811A27 / SMS 12	8/11/2016 7:30 AM	Lead	0.00219	EPA 200.8	8/19/2016	ETL	

MCL (Maximum Contaminant Level) for Lead is 0.020 mg/L.

MDL (Method Detection Limit) is 0.001 mg/L for Lead.

ND = Analyte Not Detected

All results in mg/L unless otherwise noted.

This report shall not be reproduced except in full, without the written approval of the laboratory.

The results reported relate only to the samples indicated.

Soil/solid results are reported on a dry-weight basis unless otherwise noted.

TABLE ROCK ANALYTICAL LAB
PENDLETON SCHOOL DISTRICT
419 SW 5TH STREET
PENDLETON, OR 97801

Authorized Signature

Todd Taruscio, Lab Manager

Comments:

Certifications held by Anatek Labs ID: EPA:ID00013; AZ:0701; FL(NELAP):E87893; ID:ID00013; MT:CERT0028; NM: ID00013; NV:ID00013; OR:ID200001-002; WA:C595
Certifications held by Anatek Labs WA: EPA:WA00169; ID:WA00169; WA:C585; MT:Cert0095; FL(NELAP): E871099

160811A

1st SAMP	8/11/2016	1st RCVD	8/12/2016
1st SAMP	8/11/2016	1st RCVD	8/12/2016

SMS
1st SAMP 8/11/2016 1st RCVD
UUR **PESD** Last Due

2016-2017 Lead (Water) Testing

[illegible]

ANATEK LABS RECEIVING LIST

RECEIVED INTACT ☒ TEMP: 53 °C

LABELS & CHAINS AGREE ☒ THERM# IR: 1

NO HEADSPACE ☒

ICE / ICE-PACKS PRESENT ☒

CUSTODY SEALS PRESENT ☐

PRESERVATIVES: None

NUMBER OF CONTAINERS: 3

SHIPPED VIA: air

DATE & TIME: 3/12/16 11:25 INSPECTED BY: JK

8/11/16

2/22-8/1/10