

**MAINTENANCE REPORT
AUGUST 2024**

Submitted by: Reid Reagan

Maintenance staff has been busy filling summer work order requests throughout the buildings. Painting crosswalks, handicap parking, and striping of all the schools streets and parking lots. Moving teachers from building to building per transfer. Setting up tables/chairs at the different venues for orientations and barbecues.

BHS:

Western Sports Flooring resurface/reseal the gym floor. Restore fire suppression system, fire pump was running due to low water pressure.

BMS:

Western Sports Flooring resurface/reseal the gym floor. Install new bulletin boards.

NAPI:

Western Sports Flooring resurface/reseal the gym floor.

BES:

Western Sports Flooring resurface/reseal the gym floor. Recaulk/seal windows.

BULLSHOE KW wing:

Install new pressure metering valve in heating supply line.

ANNEX:

Remove old concrete sidewalk, pour/finish concrete for new sidewalk, 130'.

BABB:

Install new fob reader, push button access in front office for access through second set of entrance doors. Replace, repress new heat supply lines.

ADMIN:

Frame/sheetrock new wall for extra storage space in the Human Resource office, relocate TV in north meeting room.