

# Memo

**To:** Board of Education  
**From:** David Nardone  
**CC:** Dr. Conway, M. Izzo  
**Date:** 6/23/2021  
**Re:** Property Update

---

## **Bradley**

Two major heat problems were resolved this month.

Repairs made to the emergency lighting system.

The boiler breaching was cleaned.

## **Irving**

Ongoing heat issues were addressed.

Lighting repairs made in hallways and bathrooms.

The boiler breaching was cleaned

## **Derby High School**

Completed preventative maintenance to classroom heaters in preparation for the heating season.

Addressed issues with the fire protection system.

## **Derby Middle School**

Rooftop unit had a motor replaced.

Boiler repairs made due to motor failure.

Eight (8) out of 16 security cameras were replaced as part of ongoing upgrade plan.

Respectfully submitted by,

David M. Nardone, Facilities Manager