

# *DERBY SCHOOLS*

**Facilities Report March 2021**

# Derby High School

- Hung sports banners in gym.
- Restored heat to main office.
- Repaired heat in room 105.
- Repairs made to front exterior door.
- Filters installed in gym and auditorium units.
- Began seasonal maintenance on exhaust fans and exterior HVAC equipment.



# Derby Middle School

- Began seasonal maintenance on exterior HVAC equipment.
- Repaired tables in art room.
- Replaced faulty door closer in B9.
- Repaired toilet in boys restroom.
- Repaired sink in A10.
- Installed new motion sensor in stairwell.



# Bradley Elementary

- Replaced circulator pump for gym units.
- Replaced gym heat unit bearings.
- Repaired toilet in girl's restroom
- Repaired partition in girl's restroom.



# Irving Elementary

- Replaced faulty outlets in Room 103.
- New alarm panel controller installed.
- Repairs made to loading dock doors.
- Elevator repairs made to control panel.
- Repaired faulty exterior door closer.
- Plumbing repairs in boys restroom.



# General

- Advertised Invitation to Bid for DHS gym floor refinishing.
- Met with architect to work on finalizing bids for summer projects.

