

Harvey Public Schools District 152
Department Of Buildings & Grounds
Mr. Charles Givines

February 2016

Buildings & Grounds Monthly Report

The following is an updated progress and scheduled service report from the department of buildings and grounds.

This month at Brooks school we have found out why the rooms on the south corridor of the building have not been getting heat to them properly. The trunk lines need to be replaced, I am working on getting this done as soon as possible.

Also our entire buildings and grounds staff attended an Asbestos Awareness Training where they learned and were certified on how to recognize asbestos and what to in case of possible exposure to Asbestos.

One of our custodial supply vendors PCS came and gave us a restroom care training on how to properly use the power washers in the restrooms for cleaning. The new machine is an Advanced All Cleaner XP it is a high pressure power washer that I have purchased from PCS. The washer will be used districtwide upon the request of the day custodians

Chuck Givines

CG/lw