

MAINTENANCE REPORT

APRIL 2025

Submitted by: Reid Reagan

Maintenance staff has been busy patching roof leaks, cleaning roof drains. Assist State of Mt Fire Marshal with fire inspections and State of Mt with boiler inspections at the schools. Plant trees around the district for Earth Day. Respond to 78 work orders, all repairs or service calls.

BHS:

Assist in the setup/teardown of Prom decorations, hang lights in the gym and lobby, setup spot lights, red carpet at entrance. Replace broken water bottle filling station with new station.

ANNEX:

Snake the drains the entire length of building, pull out baby wipes, system restored.

BULLSHOE-VC wing:

Replace faulty controller to dishwasher hot water booster, system restored.

BES:

Setup/teardown for Head Start basketball games.

NAPI:

Replace faulty gas valve supplying Lochinvar modular boiler. Replace new exhaust fan, serving the kitchen range hoods. Remove graffiti from building exterior.

BABB:

Install new bathroom faucet in girls restroom, and new ballasts (2), system restored.

ADMIN:

Install new Browning School District 9 lighted sign.