

## MAINTENANCE REPORT AUGUST 2022

Submitted by: Reid Reagan

Maintenance staff has been busy filling summer work order requests throughout the buildings. Painting crosswalks, handicap parking, and striping of all the schools. Moving teachers from building to building per transfer. Setting up tables/chairs at the different venues for orientations. MSGIA gave annual custodial refresher training. Preventive maintenance, Summit Fire Protection and Interstate Alarms did annual inspections of the buildings.

### HIGH SCHOOL:

Replace/install new air handler unit actuators for the gymnasium.

### BMS:

Install new window coverings, (7). Install 3 new digital clock/intercoms, in special services, cafetorium, and kitchen areas. Replace broken mirror in cardio/workout room.

### NAPI:

Remove/replace damaged (peeling up) floor tiles from rooms 24 and 27.

### BES:

Installed 1 new wall mount tv/monitor in classroom.

### KWB:

Install new playground equipment. Defrosted and deep clean cooler/freezer in kitchen, replace compressor to cooler.

### VC:

Defrost and deep clean cooler/freezer in kitchen.

### BABB:

Replace/install temperature control to the freezer. Replace light ballast to freezer.