

Field Notice of Violations/Unsafe Conditions

DISTRICT NAME AND NUMBER SD 45 DuPage County	COUNTY Dupage
FACILITY NAME Administration Center	FACILITY LOCATION ,

Potential problems or violations of the Health Life/Safety Code for Public Schools (23 Illinois Administrative Code Part 180) as noted below were discovered in the course of the annual inspection of the above named facility conducted on 10/29/2025 by Aaron Bacon.

Please respond within 10 days by describing the corrective action to be taken in the shaded space provided below, for each item listed. An annual inspection report summarizing your progress regarding the corrections will be submitted through IWAS on or before July 30th.

GLOSSARY NUMBER	LOCATION (Fire Area, Floor, Room Number)	DESCRIPTION OF PROBLEM
--------------------	---	------------------------

NO VIOLATIONS FOUND AT TIME OF INSPECTION

Field Notice of Violations/Unsafe Conditions

DISTRICT NAME AND NUMBER SD 45 DuPage County	COUNTY Dupage
FACILITY NAME Ardmore Elem School	FACILITY LOCATION 225 S Harvard Ave, Villa Park

Potential problems or violations of the Health Life/Safety Code for Public Schools (23 Illinois Administrative Code Part 180) as noted below were discovered in the course of the annual inspection of the above named facility conducted on 10/28/2025 by Aaron Bacon.

Please respond within 10 days by describing the corrective action to be taken in the shaded space provided below, for each item listed. An annual inspection report summarizing your progress regarding the corrections will be submitted through IWAS on or before July 30th.

GLOSSARY NUMBER	LOCATION (Fire Area, Floor, Room Number)	DESCRIPTION OF PROBLEM
--------------------	---	------------------------

NO VIOLATIONS FOUND AT TIME OF INSPECTION

Field Notice of Violations/Unsafe Conditions

DISTRICT NAME AND NUMBER SD 45 DuPage County	COUNTY Dupage
FACILITY NAME District 45 Early Childhood Center	FACILITY LOCATION 251 W Jackson St, Villa Park

Potential problems or violations of the Health Life/Safety Code for Public Schools (23 Illinois Administrative Code Part 180) as noted below were discovered in the course of the annual inspection of the above named facility conducted on 10/28/2025 by Aaron Bacon.

Please respond within 10 days by describing the corrective action to be taken in the shaded space provided below, for each item listed. An annual inspection report summarizing your progress regarding the corrections will be submitted through IWAS on or before July 30th.

GLOSSARY NUMBER	LOCATION (Fire Area, Floor, Room Number)	DESCRIPTION OF PROBLEM
95	Classrooms	Keep vision panels clear.
District's Response		
Kevin Carver Talked to SASED teacher during inspection.		

Field Notice of Violations/Unsafe Conditions

DISTRICT NAME AND NUMBER SD 45 DuPage County	COUNTY Dupage
FACILITY NAME Jackson Middle School	FACILITY LOCATION 301 W Jackson St, Villa Park

Potential problems or violations of the Health Life/Safety Code for Public Schools (23 Illinois Administrative Code Part 180) as noted below were discovered in the course of the annual inspection of the above named facility conducted on 10/28/2025 by Aaron Bacon.

Please respond within 10 days by describing the corrective action to be taken in the shaded space provided below, for each item listed. An annual inspection report summarizing your progress regarding the corrections will be submitted through IWAS on or before July 30th.

GLOSSARY NUMBER	LOCATION (Fire Area, Floor, Room Number)	DESCRIPTION OF PROBLEM
--------------------	---	------------------------

NO VIOLATIONS FOUND AT TIME OF INSPECTION

Field Notice of Violations/Unsafe Conditions

DISTRICT NAME AND NUMBER SD 45 DuPage County	COUNTY Dupage
FACILITY NAME Jefferson Middle School	FACILITY LOCATION 255 W Vermont St, Villa Park

Potential problems or violations of the Health Life/Safety Code for Public Schools (23 Illinois Administrative Code Part 180) as noted below were discovered in the course of the annual inspection of the above named facility conducted on 10/29/2025 by Aaron Bacon.

Please respond within 10 days by describing the corrective action to be taken in the shaded space provided below, for each item listed. An annual inspection report summarizing your progress regarding the corrections will be submitted through IWAS on or before July 30th.

GLOSSARY NUMBER	LOCATION (Fire Area, Floor, Room Number)	DESCRIPTION OF PROBLEM
114	Corridors	Reduce storage in Tech hallway.
District's Response		
Kevin Carver		
All boxes on west wall were removed		

Field Notice of Violations/Unsafe Conditions

DISTRICT NAME AND NUMBER SD 45 DuPage County	COUNTY Dupage
FACILITY NAME North Elem School	FACILITY LOCATION 150 W Sunset Ave, Villa Park

Potential problems or violations of the Health Life/Safety Code for Public Schools (23 Illinois Administrative Code Part 180) as noted below were discovered in the course of the annual inspection of the above named facility conducted on 10/29/2025 by Aaron Bacon.

Please respond within 10 days by describing the corrective action to be taken in the shaded space provided below, for each item listed. An annual inspection report summarizing your progress regarding the corrections will be submitted through IWAS on or before July 30th.

GLOSSARY NUMBER	LOCATION (Fire Area, Floor, Room Number)	DESCRIPTION OF PROBLEM
25	Administration and General	Keep electrical boxes in Electrical Room and Boiler Room clear (min. 36").
District's Response Kevin Carver Talked with HC and items were moved		

Field Notice of Violations/Unsafe Conditions

DISTRICT NAME AND NUMBER SD 45 DuPage County	COUNTY Dupage
FACILITY NAME Schafer Elem School	FACILITY LOCATION 700 E Pleasant Ln, Lombard

Potential problems or violations of the Health Life/Safety Code for Public Schools (23 Illinois Administrative Code Part 180) as noted below were discovered in the course of the annual inspection of the above named facility conducted on 10/29/2025 by Aaron Bacon.

Please respond within 10 days by describing the corrective action to be taken in the shaded space provided below, for each item listed. An annual inspection report summarizing your progress regarding the corrections will be submitted through IWAS on or before July 30th.

GLOSSARY NUMBER	LOCATION (Fire Area, Floor, Room Number)	DESCRIPTION OF PROBLEM
--------------------	---	------------------------

NO VIOLATIONS FOUND AT TIME OF INSPECTION

Field Notice of Violations/Unsafe Conditions

DISTRICT NAME AND NUMBER SD 45 DuPage County	COUNTY Dupage
FACILITY NAME Stevenson School	FACILITY LOCATION 18W331 15th St, Lombard

Potential problems or violations of the Health Life/Safety Code for Public Schools (23 Illinois Administrative Code Part 180) as noted below were discovered in the course of the annual inspection of the above named facility conducted on 10/28/2025 by Aaron Bacon.

Please respond within 10 days by describing the corrective action to be taken in the shaded space provided below, for each item listed. An annual inspection report summarizing your progress regarding the corrections will be submitted through IWAS on or before July 30th.

GLOSSARY NUMBER	LOCATION (Fire Area, Floor, Room Number)	DESCRIPTION OF PROBLEM
71	Boiler Room	Boiler room and adjacent custodial area could use some general housekeeping.
District's Response Kevin Carver empty boxes were removed.		

Field Notice of Violations/Unsafe Conditions

DISTRICT NAME AND NUMBER SD 45 DuPage County	COUNTY Dupage
FACILITY NAME Westmore Elem School	FACILITY LOCATION 340 S School St, Lombard

Potential problems or violations of the Health Life/Safety Code for Public Schools (23 Illinois Administrative Code Part 180) as noted below were discovered in the course of the annual inspection of the above named facility conducted on 10/28/2025 by Aaron Bacon.

Please respond within 10 days by describing the corrective action to be taken in the shaded space provided below, for each item listed. An annual inspection report summarizing your progress regarding the corrections will be submitted through IWAS on or before July 30th.

GLOSSARY NUMBER	LOCATION (Fire Area, Floor, Room Number)	DESCRIPTION OF PROBLEM
114	Corridors	Reduce storage in Kindergarten hallway.
District's Response		
Kevin Carver rolling book shelves were cleared out.		

Field Notice of Violations/Unsafe Conditions

DISTRICT NAME AND NUMBER SD 45 DuPage County	COUNTY Dupage
FACILITY NAME York Center Elem School	FACILITY LOCATION 895 E 14Th St, Lombard

Potential problems or violations of the Health Life/Safety Code for Public Schools (23 Illinois Administrative Code Part 180) as noted below were discovered in the course of the annual inspection of the above named facility conducted on 10/28/2025 by Aaron Bacon.

Please respond within 10 days by describing the corrective action to be taken in the shaded space provided below, for each item listed. An annual inspection report summarizing your progress regarding the corrections will be submitted through IWAS on or before July 30th.

GLOSSARY NUMBER	LOCATION (Fire Area, Floor, Room Number)	DESCRIPTION OF PROBLEM
4	Administration and General	Keep doors closed and locked, including PE office.
District's Response		
Kevin Carver		
14	Administration and General	Maintain clearance above storage in PE office.
District's Response		
Kevin Carver		
	Pe storage was moved	