



Dalton Refrigeration

Anchorage Mission Control
6320 Quinhagak St.
Anchorage, AK 99507
(907) 240-4440

Sales Order 862893

SALESPERSON Dallas Dalton
dallasdalton@drefrigeration.com
WORK ORDER 1550288

SHIP TO
North Slope Borough School District (907) 852-9763

BILL TO (#1149040)
North Slope Borough School District (907) 852-9763

CUST PO	CONTACT Jill Crooks Jill.Crooks@nsbsd.org (907) 852-9763
---------	--

SHIP OUT Will Call	DROP SHIP No
--------------------	--------------

ID 261631	MAKE RSD	MODEL FFAP-A30Z-TFC-075	SN 22CA1222U
-----------	----------	-------------------------	--------------

#	PART	DESCRIPTION	QTY	B/O	FILLED	RATE	DISC	NET	EXT
	Machine	Work #1550288 performed on 261631: FFAP-A30Z-TFC-075 RSD [DRH] SN: 22CA1222U Hours: 0			1.00				0.00
	NOTE	Inspected freezer in Nuiqsit at the school			1.00				0.00
1	JOB	(DRF) PRE TRIP INSPECTION (PTI)	0.00			0.00		0.00	0.00
	COMPLAINT	Nuiqsit school inside walk in freezer wont get below 5 degrees.							
	CAUSE	Box is too big for one condensing unit and one evaporator. Wall was removed between cooler and freezer so now its one big freezer. But with only one freezer condenser/evap.							
	CORRECTION	Quote will be made to remove cooler unit and install matching condensing and evap to the current freezer unit there.							
2	OUT OF TOWN - DAILY RATE	(DRF) Labor for PRE TRIP INSPECTION (PTI)	1.00		1.00	2,300.00		2,300.00	2,300.00

PAYMENT	DETAILS	DATE	AMT

COMMENTS

SUBTOTAL	2,300.00
TOTAL	2,300.00
PAYMENTS	0.00
BALANCE DUE	2,300.00

ACCEPTANCE: _____ DATE: _____