

Radon test result report for:**EDINA PUBLIC SCHOOLS
VALLEY VIEW MIDDLE SCHOOL**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11624143	101	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	0.7 ± 0.3	2023-01-31
11624151	103	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	< 0.3	2023-01-31
11624144	105	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	0.8 ± 0.3	2023-01-31
11624166	106	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	0.8 ± 0.3	2023-01-31
11624152	107	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	< 0.3	2023-01-31
11624159	108	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	0.8 ± 0.3	2023-01-31
11624160	109	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	0.6 ± 0.3	2023-01-31
11624161	111	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	0.7 ± 0.3	2023-01-31
11624167	118A	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	1.3 ± 0.3	2023-01-31
11624173	120	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	0.5 ± 0.3	2023-01-31
11624180	120A	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	< 0.3	2023-01-31
11624178	122	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	0.6 ± 0.3	2023-01-31
11624169	122A	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	0.8 ± 0.3	2023-01-31
11624174	122B	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	1.0 ± 0.3	2023-01-31
11624140	133	2023-01-24 @ 9:00 am	2023-01-27 @ 1:00 pm	1.0 ± 0.4	2023-01-31
11624135	134	2023-01-24 @ 9:00 am	2023-01-27 @ 1:00 pm	1.0 ± 0.3	2023-01-31
11624141	135	2023-01-24 @ 9:00 am	2023-01-27 @ 1:00 pm	0.7 ± 0.3	2023-01-31
11624142	136	2023-01-24 @ 9:00 am	2023-01-27 @ 1:00 pm	1.6 ± 0.4	2023-01-31
11624148	136A	2023-01-24 @ 10:00 am	2023-01-27 @ 1:00 pm	1.2 ± 0.3	2023-01-31
11624149	137	2023-01-24 @ 10:00 am	2023-01-27 @ 1:00 pm	0.7 ± 0.3	2023-01-31
11624150	138	2023-01-24 @ 10:00 am	2023-01-27 @ 1:00 pm	1.1 ± 0.3	2023-01-31
11624156	139	2023-01-24 @ 10:00 am	2023-01-27 @ 1:00 pm	0.8 ± 0.3	2023-01-31
11624137	141	2023-01-24 @ 10:00 am	2023-01-27 @ 1:00 pm	1.1 ± 0.3	2023-01-31
11624136	143	2023-01-24 @ 10:00 am	2023-01-27 @ 1:00 pm	1.0 ± 0.3	2023-01-31
11624164	144	2023-01-24 @ 10:00 am	2023-01-27 @ 1:00 pm	< 0.3	2023-01-31
11624139	145	2023-01-24 @ 10:00 am	2023-01-27 @ 1:00 pm	0.6 ± 0.3	2023-01-31
11624157	145A	2023-01-24 @ 10:00 am	2023-01-27 @ 1:00 pm	1.2 ± 0.4	2023-01-31
11624147	146	2023-01-24 @ 10:00 am	2023-01-27 @ 1:00 pm	< 0.3	2023-01-31
11624158	147	2023-01-24 @ 10:00 am	2023-01-27 @ 1:00 pm	0.7 ± 0.3	2023-01-31
11624155	149	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	0.8 ± 0.3	2023-01-31
11624172	150	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	< 0.3	2023-01-31
11624171	150A	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	< 0.3	2023-01-31
11624145	151	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	0.7 ± 0.3	2023-01-31
11624153	152	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	0.6 ± 0.3	2023-01-31
11624146	153	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	0.8 ± 0.3	2023-01-31
11624154	153A	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	0.8 ± 0.3	2023-01-31
11624130	159	2023-01-24 @ 9:00 am	2023-01-27 @ 1:00 pm	1.2 ± 0.4	2023-01-31

Radon test result report for:**EDINA PUBLIC SCHOOLS
VALLEY VIEW MIDDLE SCHOOL**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11624127	160	2023-01-24 @ 9:00 am	2023-01-27 @ 1:00 pm	1.4 ± 0.4	2023-01-31
11624134	161	2023-01-24 @ 9:00 am	2023-01-27 @ 1:00 pm	1.2 ± 0.4	2023-01-31
11624131	163	2023-01-24 @ 9:00 am	2023-01-27 @ 1:00 pm	1.6 ± 0.4	2023-01-31
11624126	164	2023-01-24 @ 9:00 am	2023-01-27 @ 1:00 pm	1.1 ± 0.3	2023-01-31
11624129	165	2023-01-24 @ 9:00 am	2023-01-27 @ 1:00 pm	1.4 ± 0.3	2023-01-31
11624123	166	2023-01-24 @ 9:00 am	2023-01-27 @ 1:00 pm	0.9 ± 0.3	2023-01-31
11624124	166A	2023-01-24 @ 9:00 am	2023-01-27 @ 1:00 pm	1.3 ± 0.4	2023-01-31
11624125	166B	2023-01-24 @ 9:00 am	2023-01-27 @ 1:00 pm	1.4 ± 0.4	2023-01-31
11624128	167	2023-01-24 @ 9:00 am	2023-01-27 @ 1:00 pm	1.3 ± 0.3	2023-01-31
11624121	168A	2023-01-24 @ 9:00 am	2023-01-27 @ 1:00 pm	1.6 ± 0.4	2023-01-31
11624120	168B	2023-01-24 @ 9:00 am	2023-01-27 @ 1:00 pm	1.5 ± 0.4	2023-01-31
11624122	168C	2023-01-24 @ 9:00 am	2023-01-27 @ 1:00 pm	1.1 ± 0.4	2023-01-31
11624114	169	2023-01-24 @ 9:00 am	2023-01-27 @ 1:00 pm	1.5 ± 0.4	2023-01-31
11605532	208	2023-01-24 @ 12:00 pm	2023-01-27 @ 3:00 pm	1.8 ± 0.4	2023-01-31
11605526	208 OFFICE	2023-01-24 @ 12:00 pm	2023-01-27 @ 3:00 pm	1.3 ± 0.4	2023-01-31
11605512	210	2023-01-24 @ 12:00 pm	2023-01-27 @ 3:00 pm	1.5 ± 0.4	2023-01-31
11605529	212 E	2023-01-24 @ 12:00 pm	2023-01-27 @ 3:00 pm	1.7 ± 0.3	2023-01-31
11605531	212 W	2023-01-24 @ 12:00 pm	2023-01-27 @ 3:00 pm	1.7 ± 0.3	2023-01-31
11605530	214	2023-01-24 @ 12:00 pm	2023-01-27 @ 3:00 pm	0.9 ± 0.4	2023-01-31
11605511	215	2023-01-24 @ 12:00 pm	2023-01-27 @ 3:00 pm	1.1 ± 0.4	2023-01-31
11605525	216	2023-01-24 @ 12:00 pm	2023-01-27 @ 3:00 pm	1.3 ± 0.4	2023-01-31
11605522	217	2023-01-24 @ 12:00 pm	2023-01-27 @ 3:00 pm	1.4 ± 0.3	2023-01-31
11624199	218	2023-01-24 @ 12:00 pm	2023-01-27 @ 1:00 pm	1.6 ± 0.4	2023-01-31
11605516	218A	2023-01-24 @ 12:00 pm	2023-01-27 @ 2:00 pm	1.2 ± 0.3	2023-01-31
11605517	218B	2023-01-24 @ 12:00 pm	2023-01-27 @ 2:00 pm	1.4 ± 0.4	2023-01-31
11605503	218C	2023-01-24 @ 12:00 pm	2023-01-27 @ 2:00 pm	1.1 ± 0.3	2023-01-31
11605504	218F	2023-01-24 @ 12:00 pm	2023-01-27 @ 2:00 pm	1.4 ± 0.3	2023-01-31
11605515	218G	2023-01-24 @ 12:00 pm	2023-01-27 @ 2:00 pm	1.0 ± 0.3	2023-01-31
11605513	219	2023-01-24 @ 12:00 pm	2023-01-27 @ 3:00 pm	1.1 ± 0.4	2023-01-31
11624200	219A	2023-01-24 @ 12:00 pm	2023-01-27 @ 1:00 pm	1.6 ± 0.4	2023-01-31
11605514	219B	2023-01-24 @ 11:00 am	2023-01-27 @ 2:00 pm	1.8 ± 0.4	2023-01-31
11605507	219C	2023-01-24 @ 11:00 am	2023-01-27 @ 2:00 pm	1.2 ± 0.3	2023-01-31
11624183	219D	2023-01-24 @ 11:00 am	2023-01-27 @ 2:00 pm	1.5 ± 0.4	2023-01-31
11605506	219E	2023-01-24 @ 11:00 am	2023-01-27 @ 2:00 pm	1.3 ± 0.4	2023-01-31
11605502	219F	2023-01-24 @ 11:00 am	2023-01-27 @ 2:00 pm	1.2 ± 0.3	2023-01-31
11605505	219H	2023-01-24 @ 11:00 am	2023-01-27 @ 2:00 pm	1.6 ± 0.4	2023-01-31
11605508	219I	2023-01-24 @ 11:00 am	2023-01-27 @ 2:00 pm	1.2 ± 0.3	2023-01-31

Radon test result report for:**EDINA PUBLIC SCHOOLS
VALLEY VIEW MIDDLE SCHOOL**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11605509	219J	2023-01-24 @ 12:00 pm	2023-01-27 @ 2:00 pm	1.3 ± 0.3	2023-01-31
11605510	219K	2023-01-24 @ 12:00 pm	2023-01-27 @ 1:00 pm	1.3 ± 0.4	2023-01-31
11624175	220 HEALTH OFFICE	2023-01-24 @ 11:00 am	2023-01-27 @ 2:00 pm	1.1 ± 0.3	2023-01-31
11624168	220B	2023-01-24 @ 11:00 am	2023-01-27 @ 2:00 pm	1.0 ± 0.3	2023-01-31
11624191	220C	2023-01-24 @ 11:00 am	2023-01-27 @ 2:00 pm	1.5 ± 0.3	2023-01-31
11624176	222	2023-01-24 @ 11:00 am	2023-01-27 @ 2:00 pm	1.5 ± 0.3	2023-01-31
11624182	229 EAST	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	< 0.3	2023-01-31
11624189	229 WEST	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	1.3 ± 0.4	2023-01-31
11624188	229C	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	0.9 ± 0.3	2023-01-31
11624187	231	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	0.9 ± 0.3	2023-01-31
11624185	235	2023-01-24 @ 11:00 am	2023-01-27 @ 2:00 pm	1.6 ± 0.4	2023-01-31
11605537	253	2023-01-24 @ 12:00 pm	2023-01-27 @ 3:00 pm	< 0.3	2023-01-31
11605538	265	2023-01-24 @ 12:00 pm	2023-01-27 @ 3:00 pm	0.8 ± 0.3	2023-01-31
11624115	CUSTODIAL OFFICE	2023-01-24 @ 9:00 am	2023-01-27 @ 1:00 pm	1.5 ± 0.4	2023-01-31
11624162	D118-1	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	1.1 ± 0.3	2023-01-31
11624163	D118-2	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	1.0 ± 0.3	2023-01-31
11624177	D126-1	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	1.2 ± 0.3	2023-01-31
11624170	D126-2	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	0.8 ± 0.3	2023-01-31
11624138	D148-1	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	0.5 ± 0.3	2023-01-31
11624165	D148-2	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	0.8 ± 0.3	2023-01-31
11624132	D163-1	2023-01-24 @ 9:00 am	2023-01-27 @ 1:00 pm	1.6 ± 0.3	2023-01-31
11624133	D163-2	2023-01-24 @ 9:00 am	2023-01-27 @ 1:00 pm	1.8 ± 0.4	2023-01-31
11624117	D168-1	2023-01-24 @ 9:00 am	2023-01-27 @ 1:00 pm	1.5 ± 0.4	2023-01-31
11624118	D168-2	2023-01-24 @ 9:00 am	2023-01-27 @ 1:00 pm	1.2 ± 0.4	2023-01-31
11605519	D207-1	2023-01-24 @ 12:00 pm	2023-01-27 @ 3:00 pm	1.0 ± 0.3	2023-01-31
11605533	D207-2	2023-01-24 @ 12:00 pm	2023-01-27 @ 3:00 pm	0.7 ± 0.3	2023-01-31
11605524	D217B-1	2023-01-24 @ 12:00 pm	2023-01-27 @ 3:00 pm	1.6 ± 0.3	2023-01-31
11605521	D217B-2	2023-01-24 @ 12:00 pm	2023-01-27 @ 3:00 pm	1.7 ± 0.3	2023-01-31
11605518	D218D-1	2023-01-24 @ 12:00 pm	2023-01-27 @ 2:00 pm	1.6 ± 0.4	2023-01-31
11605523	D218D-2	2023-01-24 @ 12:00 pm	2023-01-27 @ 2:00 pm	1.3 ± 0.3	2023-01-31
11624184	D219G-1	2023-01-24 @ 11:00 am	2023-01-27 @ 2:00 pm	1.2 ± 0.3	2023-01-31
11624192	D219G-2	2023-01-24 @ 11:00 am	2023-01-27 @ 2:00 pm	1.1 ± 0.3	2023-01-31
11624195	D220D-1	2023-01-24 @ 11:00 am	2023-01-27 @ 2:00 pm	1.0 ± 0.3	2023-01-31
11605501	D220D-2	2023-01-24 @ 11:00 am	2023-01-27 @ 2:00 pm	< 0.3	2023-01-31
11624181	DKITCHEN OFFICE-1	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	0.9 ± 0.3	2023-01-31
11624179	DKITCHEN OFFICE-2	2023-01-24 @ 10:00 am	2023-01-27 @ 2:00 pm	1.1 ± 0.3	2023-01-31
11624116	MAINTENANCE OFFICE	2023-01-24 @ 9:00 am	2023-01-27 @ 1:00 pm	1.6 ± 0.3	2023-01-31

February 1, 2023

**** LABORATORY ANALYSIS REPORT ****

Radon test result report for:

**EDINA PUBLIC SCHOOLS
VALLEY VIEW MIDDLE SCHOOL**

Kit #	Room Id	Started	Ended	pCi/L	Analyzed
11624186	MIDDLE GYM W	2023-01-24 @ 11:00 am	2023-01-27 @ 1:00 pm	1.5 ± 0.4	2023-01-31
11624193	NORTH GYM E	2023-01-24 @ 11:00 am	2023-01-27 @ 2:00 pm	1.3 ± 0.4	2023-01-31
11624194	NORTH GYM W	2023-01-24 @ 11:00 am	2023-01-27 @ 2:00 pm	1.7 ± 0.3	2023-01-31
11618803	OSTORAGE ROOM A	2023-01-24 @ 2:00 pm	2023-01-27 @ 4:00 pm	< 0.3	2023-01-31
11618807	OSTORAGE ROOM B	2023-01-24 @ 2:00 pm	2023-01-27 @ 4:00 pm	< 0.3	2023-01-31
11624196	SOUTH GYM N	2023-01-24 @ 11:00 am	2023-01-27 @ 2:00 pm	1.7 ± 0.4	2023-01-31
11624197	SOUTH GYM S	2023-01-24 @ 11:00 am	2023-01-27 @ 2:00 pm	0.9 ± 0.3	2023-01-31
11624190	THE HIVE	2023-01-24 @ 11:00 am	2023-01-27 @ 2:00 pm	1.1 ± 0.3	2023-01-31

Air Chek 1936 Butler Bridge Rd, Mills River, NC 28759-3892 Phone: (828) 684-0893 Fax: (828) 684-8498