

Harvey School District #152

District – Wide Major Repair & Maintenance Report

September/October 2012

1. Repaired & Installed New A/C-Heat Key Pad in class room & Installed New Exhaust Fan Motor for Wall Exhaust Fan in kitchen at Sandburg School
2. Removed Hot Water Boiler Tank & Install New Hot Water Boiler Tank at Brooks Middle School
3. Paper Truck Delivery District-Wide & Deliver to All Schools
4. Installed New A/C Compressor in the computer lab at Sandburg School
5. Installed New Water Faucets & Toilets & Urinals Parts District-Wide
6. Painted Interior doors at Brooks Middle School & Base Boards Installed & Repaired Floor Drain in North Hallway area & Install New Light Covers in Lecture Hall & Ceiling Tiles
7. Installed New Electrical lines for New Smart Boards at Whittier School Rooms 205,110,108 & 104. Also had Mold Removed from walls & Cracks Repaired in Room 116 and Painted for Safety
8. Repaired & (Sealed Cracks in Walls with Concrete & Painted Areas affected) at Brooks Middle School & Help New Library Staff with Removal of Items from areas as needed
9. Repaired basketball backboards and rims in the gym at Lowell & Angelou
10. Repaired Main Front Outside Doors at Angelou School & Paint Front Entry Walk way
11. Repaired A/C-Heat unit for reception area at Administration Center
12. Repaired faucet and replaced damaged floor tile outside boys washroom at Riley School
13. Had Contractor Look at Showers for Usage in Boys & Girls Shower Rooms at Brooks Middle school & repaired Class room 130 door & Install New Desk in Front Office Area
14. Replaced broken toilet in the girls washroom & Installed New 20 Amp Electrical Outlet in Main Office by Secretary Desk at Bryant School
15. Replaced burned out Sump Pump & Installed New Sump Pump in basement & Separate Electric Power in Computer Lab & Adjust Water Flow in all boys bath room Urinals & Repair Auto-Sensors at Maya Angelou School
16. Repaired Sink Leak in room 228 & Installed New Sink Faucet in room 104 for usage & Installed New Top Rails over Lockers & Repaired Front Door Leading to the upstairs 2nd floor Main Entry
17. Repaired Girls Washroom Toilet Leaks on Old side & Toilet Leaks on New side at Holmes
18. Installed New Bulletin Board on wall next to New Smart Board in room 101 at Riley Pre-K
Installed New Valve on A/C-Heat Unit & New Cooper Water Pipes in room 120 at C.O./Riley
19. Monthly Bldg. Inspections Starting with Holmes/ Lowell/ Bryant
20. District Fire Drills at Brooks & Sandburg & Fields
21. Repaired Hot Water Tank Leak in Boiler room at Fields
22. Repair (2) Boiler Pumps at Bryant & Repaired(2) Holes Outside North East Side at Bryant
23. Pre-paired our 2012/2013 Back 2 School Parade & Fair for School District's 152 & 147 with the Help of our Staff & Others
24. Action Fire Equipment Annual Service on Portable Fire Extinguishers District-Wide
25. ITR Systems Fire Alarm Inspections District-Wide
26. Purchase of New Equipment Floor Scrubber, (2) Wet Vac,& Pallet Floor Jack, (2) Secretary Desk & New Additional Cameras & Racks for Servers

Note: Minor daily operation type repairs are not listed on this report.