

# MAINTENANCE REPORT

## APRIL 2021

Submitted by: Reid Reagan

Maintenance staff has been busy patching roof leaks, assisting schools with the fire drills, and snaking backed up sewer/floor drains. Responded to 80 work orders, all repairs or service.

### HIGH SCHOOL:

Assist in the setup/teardown of Prom decorations, hang lights, and run electric wiring from panel to gym and lobby for lights and music, also the stage and entrance for the spotlights. Restore freon to supply the kitchen cooler.

### MIDDLE SCHOOL:

Big Sky Elevator repaired elevator, recommend an overhaul of cable/pulley system over the summer.

### NAPI:

Big Sky elevator repaired elevator, electrical control board, recommend replacing hydraulic pump over the summer it is starting to leak.

### BES:

Respond to backed up floor drains, run snake down line, system restored. Installed new touchless water bottle filling station, north gym lobby.

### KWB:

Respond to backed up floor drains, run snake down line, system restored.

### BABB:

Installed new touchless water bottle filling station. Kitchen's floor drain backing up, had grease trap pumped, also ran snake from cleanout nearest septic tank towards building, system restored.

### FOOD SERVICE:

Restore freon to supply for freezer.

### BUS GARAGE:

Hang new lights in shop area.