

MAINTENANCE REPORT JUNE 2022

Submitted by: Reid Reagan

Maintenance staff has been busy filling summer work order requests throughout the buildings. Doing preventive maintenance on the heating/cooling systems and air handlers, consists of replacing filters, cleaning coils and strainers, check for worn out components. Groundskeepers have been busy watering, trimming and mowing lawns. State of Mt. Fire Marshall inspected all schools, 2 violations. Montana Elevator inspected and made corrections to the 6 elevators/lifts. Responded to 32 work orders, all repairs or service calls.

HIGH SCHOOL:

Western Sports Flooring deep clean/strip and finish/seal the gym floor. Repair vent actuator in gym, controls the ventilation.

BMS:

Western Sports Flooring deep clean/strip and finish/seal the gym floor. Install plywood over the new windows, until the screens to protect windows are in place.

BES:

Western Sports Flooring deep clean/strip and finish/seal the gym floor. Installing new LED lighting throughout the school, gym is complete. Wired new 15 amp service for IT cable cabinet.

NAPI:

Western Sports Flooring deep clean/strip and finish/seal the gym floor. Repair broken irrigation pipe and valve to the football field. Repair broken sprinkler heads at football field.

VC:

Repair broken sprinkler heads on playground.

KWB:

Repair broken sprinkler heads on playground. Install new flat screen TV.

BABB:

Install new certified fire extinguisher in boiler room, per fire inspection.