Transportation and Maintenance Report

Report for November Meeting 2025

Transportation

1. Keep D.E.F. levels full, no repairs at this time.

Driftwood School

- 1. Check hot water system for cross over. Get quote to add second hot water heater to service kitchen only.
- 2. Replace ballast in light, second grade classroom.
- 3. Checked dishwasher at Driftwood kitchen. Met with repair man, ordered new booster heater.

Pacific High School

- 1. Replace door in file storage container.
- 2. Install new doors in greenhouse.
- 3. Get Locate at greenhouse for new orchard fence.
- 4. Meet with fencing contractor for orchard fence.
- 5. Remove waste water irrigation pump, pump worn out; working on quotes for replacement.
- 6. Changed out lagoon aerator in primary waste water lagoon.
- 7. Fix clogged drain in metal shop sink.
- 8. Replaced faucet fixture in District Office restroom.