

Harvey Public Schools District 152
Department Of Buildings & Grounds
Mr. Charles Givines
March 2016

Buildings & Grounds Monthly Report

The following is an updated progress and scheduled service report from the department of buildings and grounds.

- 1) Repaired water leaks at Riley School in the crawl space. (see photos)
- 2) Repaired Boilers at Fields School.
Replaced Pump on boiler 1 No. 1 (See Johnson Controls Report)
- 3) Repaired Leaking Coils at, Sandburg, Maya Angelou, Holmes, and Whittier.
- 4) Repaired sprinkler system at Bryant (See Photo)
- 5) Plowed & Salted parking lots at all schools twice in the last two weeks;
- 6) Repaired leaking pump at all school Boiler #2
- 7) Replaced battery for fire alarm at Whittier.
- 8) Put down doorstops in various Schools.
- 9) Repaired Air duct at Brooks Jr. High main trunk had ruptured not allowing air to get to 2 sections of the school. Also we were not able to control return airflow.

Chuck Givines

CG/lw