

Field Notice of Violations/Unsafe Conditions

DISTRICT NAME AND NUMBER Meridian CUSD 223	COUNTY Ogle
FACILITY NAME Highland Elem School	FACILITY LOCATION 410 S Hickory St, Stillman Valley

Potential problems or violations of the Health Life/Safety Code for Public Schools (23 Illinois Administrative Code Part 180) as noted below were discovered in the course of the annual inspection of the above named facility conducted on 10/24/2024 by Josh Knuth.

Please respond within 10 days by describing the corrective action to be taken in the shaded space provided below, for each item listed. An annual inspection report summarizing your progress regarding the corrections will be submitted through IWAS on or before July 30th.

GLOSSARY NUMBER	LOCATION (Fire Area, Floor, Room Number)	DESCRIPTION OF PROBLEM
5	Administration and General	Door B blocked by table/desks/chairs; library door blocked; gymexit corridor blocked with chair rack; corridor by room 22 blocked with desk
13	Administration and General	Repair deficiencies noted on the annual sprinkler system report
14	Administration and General	Clearance to ceiling needed in main office closets, custodial closet, book closet, kitchen storage and library storage
16	Administration and General	Mount extinguisher in gym
22	Administration and General	Fire rating needed on curtains, tent, etc. in rooms 3, 5, 7, 9
23	Administration and General	Ceiling tile in girls' and boys' restrooms
24	Administration and General	Multi plug room 9 and 20; extension cord room 10
25	Administration and General	Clearance around electrical panel in boiler room needed; open electrical of old clock on stage and kitchen; plug-in air freshener in principal's office
112	Corridors	First set of fire doors not latching in
113	Corridors	Corridor too narrow by room 22 playground exit
114	Corridors	Table/desks/chairs in corridor to Door B
115	Corridors	Excessive artwork on wall outside library
176	Kitchens	Doors need to close and latch
194	Library/Media Center (A)	Doors not latching